

LAND SURVEYOR'S CERTIFICATE AND DESCRIPTION

I, the undersigned, registered land surveyor of the State of Kansas, do hereby certify that the following described tract of land was surveyed on May 02, 2002 and the accompanying final plat prepared and that all the monuments shown herein actually exist and their positions are correctly shown to the best of my knowledge and belief:

I, Craig Moehring, Land Surveyor in the State of Kansas, do hereby certify that I have surveyed and platted "ST. MARK PARISH ADDITION", Sedgwick County, Kansas, and that the accompanying plat is a true and correct exhibit of said survey described as follows:

LEGAL DESCRIPTION

BEGINNING AT THE S.W. CORNER OF THE S.E. 1/4 OF SECTION 32, TOWNSHIP 26 SOUTH, RANGE 2 WEST OF THE 6TH P.M., SEDGWICK COUNTY, KANSAS; THENCE EAST ALONG THE SOUTH LINE OF SAID S.E. 1/4, HAVING AN ASSUMED BEARING OF S. 89°57'24" E., A DISTANCE OF 205.98 FEET; THENCE N. 00°46'50" W., PARALLEL WITH THE WEST LINE OF SAID S.E. 1/4, A DISTANCE OF 520.00 FEET; THENCE S. 89°57'24" E., PARALLEL WITH THE SOUTH LINE OF SAID S.E. 1/4, A DISTANCE OF 134.00 FEET; THENCE S. 00°46'50" E., PARALLEL WITH THE WEST LINE OF SAID S.E. 1/4, A DISTANCE OF 520.00 FEET TO A POINT ON THE SOUTH LINE OF SAID S.E. 1/4; THENCE ALONG THE SOUTH LINE HAVING AN ASSUMED BEARING OF S. 89°57'24" E., A DISTANCE OF 308.60 FEET; THENCE N. 00°46'50" W., A DISTANCE OF 1314.65 FEET; THENCE N. 89°53'41" W., A DISTANCE OF 912.58 FEET; THENCE S. 00°46'50" E., A DISTANCE OF 970.53 FEET; THENCE N. 89°56'32" W., A DISTANCE OF 131.02 FEET; THENCE S. 00°46'50" E., A DISTANCE OF 345.05 FEET TO A POINT ON THE SOUTH LINE OF THE S.W. 1/4 OF SAID SECTION 32; THENCE S. 89°56'32" E., ALONG THE SOUTH LINE OF SAID S.W. 1/4, A DISTANCE OF 395.00 FEET TO THE POINT OF BEGINNING, CONTAINING 25.73 ACRES, MORE OR LESS.

Dated Jan 31, 2003.

Craig Moehring, L.S. # 875

OWNER'S CERTIFICATE

State of Kansas)
County of Sedgwick) ss

Know all men by these presents that I, the undersigned, have caused the land described in the surveyors certificate to be platted into a lot, block, reserve and street to be known as "ST. MARK PARISH ADDITION", Sedgwick County, Kansas. Utility Easements as dedicated on the plat are hereby granted for the construction and maintenance of all public utilities. Reserve "A" is hereby reserved for use as a cemetery and shall be owned and maintained by the Catholic Diocese of Wichita, Kansas. The streets are hereby dedicated to and for the use of the public. A drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.

All abutters' rights of access to and from 29th Street North over and across the south line of lot 1 are hereby granted to the appropriate governing body, provided however that lot 1 shall have access to 29th Street North at seven locations as shall be determined by the Engineer of the appropriate governing body.

Date Signed: Feb 7, 2003

Thomas J. Olmsted, Owner
Catholic Diocese of Wichita

N LINE, S 1/2 OF
SE 1/4, SEC.
32-T26S-R2W

NOTARY CERTIFICATE

State of Kansas)
County of Sedgwick) ss

The foregoing instrument was acknowledged before me this 7th day of February 2003, by Catholic Diocese of Wichita

Claudia H. Wald, Notary Public

My Commission Expires: March 8, 2004




DEPUTY COUNTY SURVEYOR CERTIFICATE

Reviewed in accordance with K.S.A. 58-2005

on this 31st day of January 2003.

Tricia L. Robello, LS #1248
Deputy County Surveyor
Sedgwick County, Kansas

FINAL PLAT OF
"ST MARK PARISH ADDITION"
SEDGWICK COUNTY, KANSAS
IN THE SE 1/4 AND SW 1/4 OF SECTION 32, T26S, R2W OF THE 6TH P.M.



PLANNING COMMISSION CERTIFICATE

State of Kansas)
County of Sedgwick) ss

This plat of "St. Mark Parish Addition", Sedgwick County, Kansas, has been submitted to and approved by the Wichita-Sedgwick County Metropolitan Area Planning Commission, Wichita, Kansas.

Dated this ____ day of ____, 2003.

Bernard A. Hentzen, Chairman

Dale Miller, Secretary

GOVERNING BODY CERTIFICATE

State of Kansas)
County of Sedgwick) ss

The plat approval and all dedications shown hereon, if any, are accepted by the Board of County Commissioners of Sedgwick County, Kansas, this ____ day of ____, 2003.

Tim Norton, Chairman

ATTEST:

Don Brace, County Clerk

TRANSFER RECORD

Entered on transfer record this ____ day of ____, 2003.

Don Brace, County Clerk

REGISTER OF DEEDS CERTIFICATE

State of Kansas)
County of Sedgwick) ss

This is to certify that this instrument was filed for record in the Register of Deeds Office on

the ____ day of ____, 2003,

at ____ o'clock ____ M. and is duly recorded.

Bill Meek, Register of Deeds

Linda Kizzire, Deputy

LEGEND:

- = SET 3/4" PIPE WITH CAP
- = FOUND 5/8" REBAR WITH ARMSTRONG CAP
- △ = SECTION CORNER

Date of Preparation: October 11, 2002

Closure Computation
Northing Error=0.010'
Easting Error=0.006'
Error of Closure=0.012'
Length=5,757.410'
Accuracy 1:479,784

BENCHMARK:
TOP OF IRON, SW COR., SE 1/4, SEC. 32-26-W,
ELEVATION = 1440.57 M.S.L.



Wichita-Sedgwick County Metropolitan Area Planning Department

December 19, 2002

Harlan Foraker
Certified Engineering Design, P.A.
8109 W. Douglas, Ste. C.
Wichita, KS 67203

RE: SUB 2002-122 -- One-Step Final Plat of St. Marks Addition

At the regular meeting of the Metropolitan Area Planning Commission on December 19, 2002, the above captioned plat was considered. The action of the Planning Commission was to approve the plat as recommended by the Subdivision Committee, subject to the conditions stated in our letter dated December 13, 2002.

The following items must be submitted to the Metropolitan Area Planning Department before the plat is scheduled for the City Council and/or County Commission's consideration:

1. A completed and signed tracing of the subdivision, along with four (4) copies. Also, if a change is required on the tracing after submittal, four (4) revised copies must be submitted;
2. A check, made out to the Register of Deeds, covering the costs of any documents to be recorded as a requirement of platting. (Cost: \$8.00 for the first page; \$4.00 for each additional page); and
3. A disk, which will be used by the City and County GIS Departments, detailing the final plat in digital format in Autocad.

Prior to the plat being released, a detailed Lot Grading Plan must be submitted to the Engineering Department (this applies to all multi-lot, residential developments).

If you have any questions regarding this plat, please call.

Neil Evan Strahl, Senior Planner
Current Plans Division

NES:ch

City Hall • 10th Floor • 455 North Main • Wichita, Kansas 67202-1688

T 316.268.4421 F 316.268.4390

www.wichitagov.org



Wichita-Sedgwick County Metropolitan Area Planning Department

December 13, 2002

Harlan Foraker
Certified Engineering Design, P.A.
8109 W. Douglas, Ste. C.
Wichita, KS 67203

RE: SUB 2002-122 -- One-Step Final Plat of St. Marks Addition

At the regular meeting of the Subdivision Committee of the Metropolitan Area Planning Commission on Thursday, December 12, 2002, the above captioned plat was considered. The action of the Committee was to approve the one-step final plat, subject to the following staff comments:

- A. The final plat shall be submitted with a revised name as an Addition now exists with the name "St. Mark Addition".
- B. Since sanitary sewer is unavailable to serve this property, the applicant shall contact **County Code Enforcement** to find out what tests may be necessary and what standards are to be met for approval of on-site sewerage facilities. A memorandum shall be obtained specifying approval.
- C. The site is currently located within the Rural Water District No. 4. The applicant shall contact this water district to determine the ability of this property being platted to connect to their water line and submit a letter to MAPD and **County Code Enforcement** from the water district to that effect.
- D. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning Department for recording.
- E. **County Engineering** needs to comment on the status of the applicant's drainage plan. **A drainage plan is needed.**
- F. The plat proposes seven access openings along 29th St. North. Distances should be shown for all segments of access control. The final plat tracing shall reference the dedication of access controls in the plat's text. **The Subdivision Committee has approved all proposed openings.**

City Hall • 10th Floor • 455 North Main • Wichita, Kansas 67202-1688

T 316.268.4421 F 316.268.4390

www.wichitagov.org

- G. The applicant shall guarantee the closure of any driveway openings located in areas of complete access control or that exceed the number of allowed openings.
- H. The portion of the cemetery site involved in burials is recommended to be platted as a Reserve. The Reserve description of uses should allow for these features, uses, and non-habitable structures associated with a cemetery.
- I. The 20-ft water easement needs to be located.
- J. On the final plat tracing, the MAPC signature block needs to reference "Bernard A. Hentzen, Chair".
- K. "Colwich" needs to be removed from the title of the plat.
- L. The platator's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- M. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- N. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- O. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (Phone 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- P. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- Q. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- R. Perimeter closure computations shall be submitted with the final plat tracing.
- S. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.

- T. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property. Southwestern Bell has requested additional easements.
- U. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.

If this plat requires the guaranteeing of improvements, a list of the five (5) methods that have been adopted as being acceptable is available in the Planning Department. Also available, are Certificates that are required if petitions are submitted, bond forms and Irrevocable Letter of Credit forms.

This case will be forwarded to the Planning Commission for consideration on Thursday, December 19, 2002, at 1:00 p.m.

The enclosed "marked" copy of the plat is for your information and files.

If you have any questions regarding this plat, please call.



Neil Evan Strahl, Senior Planner
Current Plans Division

NES:ch

Enclosure: Marked Copy of Plat

Copies to: Catholic Diocese of Wichita, 424 N. Broadway, Wichita, KS 67202
Craig Moehring, Moehring and Associates, 433 S. Hydraulic, Wichita, KS 67211
Walter Rooney, Sedgwick County Fire Department
Neil Cable, City Engineer, Department of Engineering
Jim Weber, PE-Director, Sewer Operations & Maintenance Department, Bureau of Public Services

STAFF REPORT
(ONE-STEP FINAL PLAT APPROVED 12/12/02)

CASE NUMBER: SUB 2002-122 -- ST. MARK ADDITION

OWNER/APPLICANT: Catholic Diocese of Wichita, 424 North Broadway, Wichita, KS 67202

AGENT: Certified Engineering Design, P.A., 810 W. Douglas, Suite C, Wichita, KS 67203

SURVEYOR/ENGINEER: Moehring & Associates, 433 S. Hydraulic, Wichita, KS 67211

LOCATION: West of 183rd St. West, North side of 29th St. North

SITE SIZE: 28.12 acres

NUMBER OF LOTS


Residential:	1
Office:	
Commercial:	
Industrial:	
Total:	1

MINIMUM LOT AREA: 26.79 acres

CURRENT ZONING: RR, Rural Residential

PROPOSED ZONING: Same

VICINITY MAP



SUB 2002-122 -- One-Step Final Plat of ST. MARK ADDITION
December 19, 2002 - Page 2

NOTE: This site is located in the County in an area designated as "rural" by the 1999 Update to the Wichita-Sedgwick County Comprehensive Plan.

Planning Staff recommends approval of the plat.

STAFF COMMENTS:

- A. The final plat shall be submitted with a revised name as an Addition now exists with the name "St. Mark Addition".
- B. Since sanitary sewer is unavailable to serve this property, the applicant shall contact **County Code Enforcement** to find out what tests may be necessary and what standards are to be met for approval of on-site sewerage facilities. A memorandum shall be obtained specifying approval.
- C. The site is currently located within the Rural Water District No. 4. The applicant shall contact this water district to determine the ability of this property being platted to connect to their water line and submit a letter to MAPD and **County Code Enforcement** from the water district to that effect.
- D. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning Department for recording.
- E. **County Engineering** needs to comment on the status of the applicant's drainage plan. **A drainage plan is needed.**
- F. The plat proposes seven access openings along 29th St. North. Distances should be shown for all segments of access control. The final plat tracing shall reference the dedication of access controls in the plat's text. **The Subdivision Committee has approved all proposed openings.**
- G. The applicant shall guarantee the closure of any driveway openings located in areas of complete access control or that exceed the number of allowed openings.
- H. The portion of the cemetery site involved in burials is recommended to be platted as a Reserve. The Reserve description of uses should allow for these features, uses, and non-habitable structures associated with a cemetery.
- I. The 20-ft water easement needs to be located.
- J. On the final plat tracing, the MAPC signature block needs to reference "Bernard A. Hentzen, Chair".
- K. "Colwich" needs to be removed from the title of the plat.
- L. The plat's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.

SUB 2002-122 -- One-Step Final Plat of ST. MARK ADDITION
December 19, 2002 - Page 3

- M. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- N. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- O. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (Phone 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- P. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- Q. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- R. Perimeter closure computations shall be submitted with the final plat tracing.
- S. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- T. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property. **Southwestern Bell has requested additional easements.**
- U. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.