


FINAL PLAT


REED COMMERCIAL ADDITION

AN ADDITION TO WICHITA, SEDGWICK COUNTY, KANSAS



LEGEND

- = FOUND PROPERTY CORNER
- = 5/8\" REBAR/MKEC CLS #39 SET
- △ = SECTION CORNER MONUMENT
- (M) = MEASURED



"REED COMMERCIAL ADDITION" is subject to the conditions of Community Unit Plan (DP-222)

I, Gregory J. Allison, a Registered Land Surveyor in Kansas, do hereby certify that I have been in responsible charge of surveying and platting of "REED COMMERCIAL ADDITION", an addition to Wichita, Sedgwick County Kansas, into lots, a block, and streets, the same being accurately set forth in the accompanying plat and described herein:

A tract of land lying in the Northwest Quarter, Section 11, Township 27 South, Range 2 East of the 6TH P.M., Sedgwick County, Kansas, more particularly described as follows:

Beginning 40.00 feet South of the North line of said Northwest Quarter and 30.00 feet East of the West line of said Northwest Quarter; thence parallel with the North line of said Northwest Quarter on a NAD 88 Kansas South Zone Grid Bearing of, N88°33'26"E, 1098.05 feet; thence parallel with the West line of said Northwest Quarter S00°51'36"E, 843.03 feet; thence S88°33'26"W, 1098.05 feet to a point 30.00 feet East of the the West line of said Northwest Quarter; thence parallel with said West line of said Northwest Quarter N00°51'36"W, 843.03 feet to the Point of Beginning.

I hereby certify that the details of this plat are correct to the best of my knowledge and belief this ____ day of _____, 2002.

Gregory J. Allison, LS #1257
MKEC Engineering Consultants, Inc.
411 North Webb Road
Wichita, KS 67206

Know all men by these presents that we the undersigned property owners of the land as above set forth in the Registered Land Surveyor's Certificate, have caused the same to be surveyed and platted into lots, a block, and streets, the same to be known as "REED COMMERCIAL ADDITION", an addition to Wichita, Sedgwick County, Kansas. Easements for the construction and maintenance of public utilities and drainage are hereby granted to the public. The wall easement is platted for the construction and maintenance of a private wall. Utilities may cross the wall easement. All abutters right of access to or from 21st Street North over and across the North line of "REED COMMERCIAL ADDITION," are hereby granted to the appropriate governing body, provided however, Lot 3, Block 1 shall have access to 21st Street at one location, and Lot 1, Block 1, shall have access to 21st Street at one location, and Lots 4 and 5, Block 1 shall share one common access to 21st Street, as indicated on the face of the plat, and also, all abutters right of access to or from 127th Street East over and across the West line of "REED COMMERCIAL ADDITION," are hereby granted to the appropriate governing body, provided however, Lot 2 and 3, Block 1 shall share one common access to 127th Street, and Lot 1, Block 1, shall have access to 127th Street at two locations, as indicated on the face of the plat. A drainage plan has been developed for the plat and all drainage easements, and rights-of-way, shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater. "REED COMMERCIAL ADDITION" is subject to the conditions of Community Unit Plan (DP-222).

21/127 L.C., a Kansas Limited Liability Company

_____, President
Kevin M. Mullen, President
Ritchie Associates, Inc., a Kansas Corporation, Manager

STATE OF KANSAS)

) ss:

SEDGWICK COUNTY)

BE IT REMEMBERED, that on this ____ day of _____, 2002, before me the undersigned, a Notary Public in and for the County and State aforesaid, came Kevin M. Mullen, President, 21/127 L.C., a Kansas Limited Liability Company, Ritchie Associates, Inc., a Kansas Corporation, Manager to me personally known to be the same person who executed the foregoing instrument of writing and duly acknowledged the execution of the same.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed my official seal, the day and year last above written.

Notary Public

My commission expires: _____

_____, Owner
Clarence M. Mallett, Owner

STATE OF KANSAS)

) ss:

SEDGWICK COUNTY)

BE IT REMEMBERED, that on this ____ day of _____, 2002, before me the undersigned, a Notary Public in and for the County and State aforesaid, came Clarence M. Mallett, owner to me personally known to be the same person who executed the foregoing instrument of writing and duly acknowledged the execution of the same.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed my official seal, the day and year last above written.

Notary Public

My commission expires: _____

We, INTRUST Bank, N.A., holders of a mortgage on the above described property, do hereby consent to the plat of "REED COMMERCIAL ADDITION".

INTRUST Bank, N.A.

STATE OF KANSAS)

) ss:

SEDGWICK COUNTY)

BE IT REMEMBERED, that on this ____ day of _____, 2002, before me the undersigned, a Notary Public in and for the County and State aforesaid, came _____, to me personally known to be the same person who executed the foregoing instrument of writing and duly acknowledged the execution of the same.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed my official seal, the day and year last above written.

Notary Public

My appointment expires: _____

This plat of "REED COMMERCIAL ADDITION", has been submitted to and approved by the Wichita-Sedgwick County Metropolitan Area Planning Commission, Wichita, Kansas.

Dated this ____ day of _____, 2001.

WICHITA-SEDGWICK COUNTY METROPOLITAN AREA PLANNING COMMISSION

_____, Chair
J.D. Michaelis, Chair

_____, Secretary
Dale Miller, Secretary

This plat approved and all dedications shown thereon, if any, accepted by the City Council of the City of Wichita, Kansas, this ____ day of _____, 2002.
At the direction of the City Council

_____, City Manager
Chris Cherches, City Manager

_____, City Clerk
Pat Graves, City Clerk

Entered on transfer record this ____ day of _____, 2002.

_____, County Clerk
Don Brace, County Clerk

STATE OF KANSAS)

) ss:

SEDGWICK COUNTY)

This is to certify that this instrument was filed for record in the Register of Deeds office this ____ day of _____, 2002 at ____ o'clock ____ M; and duly recorded.

_____, Register of Deeds
Bill Meek, Register of Deeds

_____, Deputy
Linda Kizzire, Deputy

Reviewed in accordance with K.S.A. 58-2005 on this ____ day of _____, 2002.

_____, Deputy
Tricia L. Robello, LS #1246
Deputy County Surveyor
Sedgwick County, Kansas



Wichita-Sedgwick County Metropolitan Area Planning Department

October 15, 2001

Mid-Kansas Engineering Consultants, Inc.
411 N. Webb Road
Wichita, KS 67206


RE: S/D 99-86 -- Final Plat of Reed Commercial Addition

At the regular meeting of the Metropolitan Area Planning Commission on October 11, 2001, the above captioned plat was considered. The action of the Planning Commission was to approve the plat as recommended by the Subdivision Committee, subject to the conditions stated in our letter dated September 28, 2001.

In addition to complying with those conditions, it is necessary that you meet the following requirements before this plat can be forwarded to the City Council and/or County Commission for consideration:

1. Submission of the fully completed and signed tracing of the subdivision, along with four (4) copies, to the Metropolitan Area Planning Department.
2. Submission of a check, made out to the Register of Deeds, covering the costs of any documents to be recorded as a requirement of platting.
3. Subdivision regulations now require a detailed Lot Grading Plan be submitted to Engineering prior to the tracing being released. This applies to all multi-lot, residential developments.
4. Submission of a disk to the Planning Department detailing the final plat in digital format in Autocad. This will be used by the City and County GIS Departments.

If you have any questions concerning this matter, please call.


Neil Evan Strahl, Senior Planner
Current Plans Division
NES:ch

City Hall • 10th Floor • 455 North Main • Wichita, Kansas 67202-1688

T 316.268.4421 F 316.268.4390

www.wichitagov.org



Wichita-Sedgwick County Metropolitan Area Planning Department

September 28, 2001

Mid-Kansas Engineering Consultants, Inc.
411 N. Webb Road
Wichita, KS 67206

RE: S/D 99-86 -- Final Plat of Reed Commercial Addition

At the regular meeting of the Subdivision Committee of the Metropolitan Area Planning Commission on Thursday, September 27, 2001, the above captioned plat was considered. The action of the Committee was to approve the final plat, subject to the following:

STAFF COMMENTS:

- A. As this site is adjacent to Wichita's city limits, the applicant shall submit a request for annexation.
- B. City Engineering needs to indicate the status of City water and sanitary sewer services for this site and the need for guarantees. A guarantee shall be submitted for sewer and water extensions. An off-site sewer easement is required.
- C. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- D. City/County Engineering needs to comment on the status of the applicant's drainage plan. City Engineering has required an off-site drainage agreement and an on-site detention system. County Engineering requires renewed final drainage plan to determine impact of the drainage on the 21st St. Right of Way.
- E. In the legal description, the bearing of N0051'36"W needs to be corrected to N00°51'36"W.
- F. In accordance with the CUP approved for the site, the plat proposes three access openings along both 21st St. North and 127th St. East. No openings shall be permitted along 127th St. East until a paving guarantee is provided. Distances shall be shown for all segments of access control. In accordance with the Subdivision regulations, access points are limited to right turns only for the two openings closest to the intersection; and shall be denoted on the face of the plat. The final plat shall reference the access controls in the plat's text.

City Hall • 10th Floor • 455 North Main • Wichita, Kansas 67202-1688

T 316.268.4421 F 316.268.4390

www.wichitagov.org

- G. In accordance with the CUP, the Applicant shall provide a guarantee for a left turn lane on 127th St. East, a left turn lane on 21st St. North to the major opening, and a continuous right turn lane on 21st Street North.
- H. On the final plat, a note shall be placed on the face of the plat indicating that this Addition is subject to the conditions of Community Unit Plan (DP-222)
- I. A CUP Certificate shall be submitted to MAPD prior to City Council consideration, identifying the approved CUP and its special conditions for development on the property.
- J. On the final plat tracing, the MAPC signature block needs to reference "J.D. Michaelis, Chair".
- K. The platlor's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- L. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- M. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- N. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (Phone 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- O. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- P. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- Q. Perimeter closure computations shall be submitted with the final plat tracing.
- R. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.

S/D 99-86 -- Final Plat of Reed Commercial Addition
September 28, 2001
Page 3

- S. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property. *Southwestern Bell has requested additional easements.*
- T. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.

This case will be forwarded to the Planning Commission on Thursday, October 11, 2001, at 1:30 p.m.

The enclosed "marked" copy of the plat is for your information and files.
If you have any questions concerning this matter, please call.



Neil Evan Strahl, Senior Planner
Current Plans Division

NES:ch

Copies to: 21/127 L.C., 8100 E. 22nd Street North, Bldg. 1000, Wichita, KS 67226
Clarence Mollett, 2515 Briarwood Lane, Hutchinson, KS 67502
Mike Lindebak, City Engineering, Mail Stop (1-71)
Jim Weber, PE-Director, Sewer Operations & Maintenance Department, Bureau of Public Services, 1144 S. Seneca, Wichita, KS 67213

STAFF REPORT

(Final Plat Approved 9/27/01; Preliminary Plat Approved 12/2/99)

CASE NUMBER: S/D 99-86 -- REED COMMERCIAL ADDITION

OWNER/APPLICANT: 21/127 L.L.C., 8100 E. Rock Road, Building 1000, Wichita, KS 67226; Clarence Mollett, 2515 Briarwood Lane, Hutchinson, KS 67502

SURVEYOR/ENGINEER: Mid Kansas Engineering Consultants, Inc., 411 North Webb Road, Wichita, KS 67206

LOCATION: Southeast corner of 21st St. North and 127th St. East

SITE SIZE: 20.02 Acres


NUMBER OF LOTS

Residential:	
Office:	
Commercial:	5
Industrial:	
Total:	5

MINIMUM LOT AREA: 1.15 Acres

CURRENT ZONING: SF-20, Single-Family Residential

PROPOSED ZONING: LC, Limited Commercial

VICINITY MAP

NOTE: This site has been approved for a zone change (SCZ-0712) from SF-20, Single-Family Residential to LC, Limited Commercial and is also subject to the Reed Property Commercial Community Unit Plan (DP-222). The site is located in the County adjoining Wichita's city limits.

STAFF COMMENTS:

- A. As this site is adjacent to Wichita's city limits, the applicant shall submit a request for annexation.
- B. **City Engineering** needs to indicate the status of City water and sanitary sewer services for this site and the need for guarantees. *A guarantee shall be submitted for sewer and water extensions. An off-site sewer easement is required.*
- C. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- D. **City/County Engineering** needs to comment on the status of the applicant's drainage plan. *City Engineering has required an off-site drainage agreement and an on-site detention system. County Engineering requires renewed final drainage plan to determine impact of the drainage on the 21st St. Right of Way.*
- E. In the legal description, the bearing of N0051'36"W needs to be corrected to N00°51'36"W.
- F. In accordance with the CUP approved for the site, the plat proposes three access openings along both 21st St. North and 127th St. East. No openings shall be permitted along 127th St. East until a paving guarantee is provided. Distances shall be shown for all segments of access control. In accordance with the Subdivision regulations, access points are limited to right turns only for the two openings closest to the intersection; and shall be denoted on the face of the plat. The final plat shall reference the access controls in the plat's text.
- G. In accordance with the CUP, the Applicant shall provide a guarantee for a left turn lane on 127th St. East, a left turn lane on 21st St. North to the major opening, and a continuous right turn lane on 21st Street North.
- H. On the final plat, a note shall be placed on the face of the plat indicating that this Addition is subject to the conditions of Community Unit Plan (DP-222)
- I. A CUP Certificate shall be submitted to MAPD prior to City Council consideration, identifying the approved CUP and its special conditions for development on the property.
- J. On the final plat tracing, the MAPC signature block needs to reference "J.D. Michaelis, Chair".
- K. The plat's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- L. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)

- M. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- N. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (Phone 316-946-4556) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- O. The applicant is advised that various State and Federal requirements (specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147) for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- P. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- Q. Perimeter closure computations shall be submitted with the final plat tracing.
- R. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- S. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property. **Southwestern Bell has requested additional easements.**
- T. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.