



REBAR SCHEDULE

Bar	Shape	No.	Length	Weight
a1	[]	1	17'10"	11.91
a2	[]	1	16'0"	10.69
a3	[]	1	15'7"	10.41
a4	[]	1	15'2"	10.13
a5	[]	1	14'9"	9.82
a6	[]	1	14'4"	9.57
a7	[]	1	13'11"	9.30
a8	[]	1	13'5"	8.96
a9	[]	1	13'0"	8.68
a10	[]	1	12'7"	8.41
a11	[]	1	12'2"	8.13
a12	[]	1	11'9"	7.85
b1	[]	2	11'8"	15.59
b2	[]	2	8'8"	11.58
b3	[]	2	11'10"	15.81
c	[]	7	14'0"	65.46
d1	[]	4	1'2"	3.12
d2	[]	4	8"	1.78
e	[]	3	6'6"	13.03
f	[]	4	3'4"	8.91
g	[]	3	9'3"	18.54
h	[]	7	2'9"	12.86
Total Rebar				280.54 Lbs.
Concrete				4.91 C.Y.

REBAR SCHEDULE

Bar	Shape	No.	Length	Weight
a1	[]	1	17'10"	11.91
a2	[]	1	16'0"	10.69
a3	[]	1	15'7"	10.41
a4	[]	1	15'2"	10.13
a5	[]	1	14'9"	9.82
a6	[]	1	14'4"	9.57
a7	[]	1	13'11"	9.30
a8	[]	1	13'5"	8.96
a9	[]	1	13'0"	8.68
a10	[]	1	12'7"	8.41
a11	[]	1	12'2"	8.13
a12	[]	1	11'9"	7.85
b1	[]	2	11'8"	15.59
b2	[]	2	8'8"	11.58
b3	[]	2	11'10"	15.81
c	[]	7	14'0"	65.46
d1	[]	4	1'2"	3.12
d2	[]	4	8"	1.78
e	[]	3	6'6"	13.03
f	[]	4	3'4"	8.91
g	[]	3	9'3"	18.54
h	[]	7	2'9"	12.86
Total Rebar				280.54 Lbs.
Concrete				4.91 C.Y.

GENERAL NOTES

1. ALL PIPES SHALL BE FLUSH CUT PRIOR TO BEING CAST INTO CONCRETE HEADWALL
2. CONCRETE USED IN HEADWALL CONSTRUCTION SHALL BE SAME AS PER CITY STANDARD PAVING MIX EXCEPT THAT IT SHALL HAVE A MINIMUM 28 DAY COMPRESSIVE STRENGTH OF 4000 PSI.
3. ALL EXPOSED EDGES SHALL BE BEVELED 1/2" .
4. REINFORCING STEEL SHALL COMPLY TO A.S.T.M. DESIGNATION A615 GRADE 60. ALL DIMENSIONS RELATIVE TO REINFORCING STEEL ARE TO CENTERLINE OF BAR UNLESS OTHERWISE NOTED.
5. THE "REIN. CONC. HEADWALL" SHALL BE PAID FOR AT THE UNIT PRICE BID PER EACH IN PLACE WHICH SHALL INCLUDE ALL LABOR, MATERIALS, EXCAVATION, CONCRETE, REINFORCING STEEL AND ALL OTHER INCIDENTAL ITEMS NECESSARY TO COMPLETE THE WORK. MATERIAL QUANTITIES SHOWN ARE FOR INFORMATION ONLY.

Baughman
HEADWALL DETAIL

Baughman Company, P.A. 315 Elm St. Woburn, MA 02158
 ENGINEERING | SURVEYING | PLANNING | LANDSCAPE ARCHITECTURE
 PROJECT NUMBER: 40834395
 DESIGN: JAK
 APPROVED: JAK
 DATE: 09/07

SCALE: Noted
 SHEET: 28 OF 51

HEADWALL FOR 48" RCP

SPECIAL HEADWALL FOR 48" RCP

A Deduction in Concrete Quantities Has Been Made for Pipe Openings Through the Headwall
 * Field Bend or Cut Reinforcing as Required for Clearance.
 All Concrete Reinforcement to be #4 Rebar.
 All Rebar to Have Min. of 1 1/2" Conc. Cover.

A Deduction in Concrete Quantities Has Been Made for Pipe Openings Through the Headwall
 * Field Bend or Cut Reinforcing as Required for Clearance.
 All Concrete Reinforcement to be #4 Rebar.
 All Rebar to Have Min. of 1 1/2" Conc. Cover.