


DRAINAGE AREA "C" = 0.71 ACRES
 0.02 AC. GRASS (C=0.45)
 0.69 AC. IMPERV. (C=0.95)
 $C_w = 0.94$
 $T_c = 10 \text{ min.}$
 $I_s = 5.34$ $I_{100} = 8.54$
 $Q_5 = 3.6 \text{ cfs}$
 $Q_{100} = 5.7 \text{ cfs}$
 (EXISTING)

DRAINAGE AREA "A" = 0.77 ACRES
 0.05 AC. GRASS (C=0.45)
 0.72 AC. IMPERV. (C=0.95)
 $C_w = 0.92$
 $T_c = 10 \text{ min}$ $I_s = 5.34$ $I_{100} = 8.54$
 $Q = C I A$
 $Q_5 = 3.8 \text{ cfs}$ $Q_{100} = 6.0 \text{ cfs}$
 2'x2' INLET CAPACITY = 3.0 cfs
 @ 0.5' h $Q = 0.6 A T^{2/3} h$
 PER ACPI DESIGN DATA 4"
 12" RCP OR PVC WILL FLOW 3.6 cfs @ 1.0%

DRAINAGE AREA "B" = 0.37 ACRES
 0.05 AC. GRASS 0.32 AC. IMPERV.
 $C_w = 0.88$
 $T_c = 10 \text{ MIN.}$ $I_s = 5.34$ $I_{100} = 8.54$
 $Q_5 = 1.7 \text{ cfs}$ $Q_{100} = 2.8 \text{ cfs}$
 PER ACPI
 8" PIPE @ 1.0% WILL FLOW 1.2 cfs
 $Q_p = 70\% \text{ OF } Q_5$

DRAINAGE
 CALCULATIONS
 2-2-04
 JCR

FURNITURE ON CONSIGNMENT
 PARTIAL GRADING PLAN
 1400 N. TERRACE, WICHITA, KANSAS

 Ruggles & Bohm, P.A. Engineering, Surveying, Land Planning 624 North Main Wichita, Kansas 67202 www.rbkansas.com	TOR BA REVIEW DATE	2 of 5
	(316) 264-4008 (316) 264-4021 fax E-mail: info@rbkansas.com	PROJECT NUMBER DATE Feb. 2, 2004

