



Contractor shall include 2 wraps of mastic or rubber gaskets (natural or synthetic) at each joint in the manhole. Provide exterior bituminous coating. (One coat Valspar high-build Bituminous coating 35-J-10, or Tnemec 46-450 Heavy Tnemecol or approved equal).

NUMBER	DESCRIPTION	COORDINATES		ELEVATION
1	NW. COR. CONC. APRON	N 17736.62	E 20686.48	1321.75
2	SW. COR. CONC. APRON	N 17690.21	E 20686.42	1321.75
3	SE. COR. CONC. APRON	N 17690.15	E 20722.60	1321.75
4	NE. COR. CONC. APRON	N 17736.59	E 20722.65	1321.75
5	CL DRIVE	N 17715.80	E 20673.99	1321.33
6	CL DRIVE	N 17715.75	E 20723.05	1321.60
7	BOLLARD	N 17722.05	E 20683.51	1321.80
8	BOLLARD	N 17721.77	E 20688.42	1321.80
9	BOLLARD	N 17721.72	E 20704.12	1321.80
10	BOLLARD	N 17708.74	E 20683.31	1321.80
11	BOLLARD	N 17708.60	E 20688.42	1321.80
12	BOLLARD	N 17708.76	E 20703.96	1321.80
13	CTR. WET WELL	N 17703.84	E 20694.72	1322.00
14	CTR. VALVE VAULT	N 17702.56	E 20707.98	1322.00
15	CTR. UTILITY SHELTER	N 17727.50	E 20697.33	1322.00
16	CTR. GENERATOR PAD	N 17727.58	E 20713.00	1322.00

REV. 7-10-07

<b>MAIN 16, SS #23</b> <b>LIFT STATION DETAILS</b> <b>CITY OF WICHITA, KANSAS</b>			
	<b>Ruggles &amp; Bohm, P.A.</b> Engineering, Surveying, Land Planning		DESIGN PDC DRAWN PDC REVIEW UTILITY
	924 North Main Wichita, Kansas 67203 www.rbkansas.com		(316) 264-8008 (316) 264-4621 fax E-mail: info@rbkansas.com
DRAWING FILE KDOT Lift Sta. engg.		PROJECT NUMBER .	
		DATE Apr. 28, 2006	
			SHEET <b>15</b> OF <b>24</b>