



LOCATION MAP
 ALTERATION OF PART OF SAN. SEWER 1
 CITY OF WICHITA
 B.E. SMITH CITY ENGINEER PROJECT NO. C26-33


Surveyed by B. E. Smith
 Checked by J. L. Smith
 Date 1-1-57





B. E. Smith
 City Engineer
 1/1/57


Alteration of Part of San. Sewer #1
 Project No. C26-33 Sheet 1 of 7
 JAN. 1957
















PLAN
REINF. CONC. M.H. - STA 0+00
Scale 3/8" = 1'



SECTIONAL PLAN
REINF. CONC. M.H. - STA 0+00
Scale 3/8" = 1'



SECTION - 1
REINF. CONC. M.H. - STA 0+00
Scale 3/8" = 1'

NOTE:
4 Extra #6 Bars
around 36" R.C.P.
in walls.
3 extra #6 bars in
bottom of roof slab


NOTE:
PLUGS FOR ABANDONED
SEWERS TO BE IN 12" MASONRY
OR 7 SACK CONCRETE.

NOTE:
Steel Pattern - 2 Mats
of #5 bars @ 12" Ctrs. in
Roof, Walls, and Base,
Except As Noted.
Extra Diagonal Bars
around Opening To be
Used As Shown.


Manhole Inverts are to
be of Paved Concrete. The
Concrete Fill shall be
shaped to the radius of
the sewer pipe so that
smooth flow lines will
result.

Inside Top & Walls of
Manhole Structures To be
lined with Plastic. The
Plastic Lining shall extend
a minimum of 6" below top
of invert fill. No lining
required on concrete fill
invert of Manhole Structure
or on Brick Manhole
Barrel.


Plastic Sheets for
Lining Structure Wall and
Roof Surfaces shall be
Amer. Plate "T" Lock Liner
Plate As Manufactured by
Amercoat Corp., or An
Approved Equal. Minimum
Thickness of Liner .36".




PLAN
REINF. CONC. M.H. - STA 4+34
Scale 3/8" = 1'



SECTIONAL PLAN
REINF. CONC. M.H. - STA 4+34
Scale 3/8" = 1'



SECTION - 2
REINF. CONC. M.H. - STA 4+34
Scale 3/8" = 1'



RAILROAD CROSSING DETAIL
ON HARRY STREET
Scale 3/8" = 1'

ALL DIMENSIONS OF S.S. 1
C66-33 Sheet Top 7