

NOTE:

All 6" V.C.P. leads to be enclosed with 8" reinforced concrete encasement.
See 125' grade on all 6" leads.
Joints on 6" pipe shall be PVC.

NOTE To Field Engineer:

Set stationing at both ends of all 6" leads and put five diagonal and perpendicular distances from the 6" leads.

Surveyed by J. E. Smith, Jr.
Checked by J. E. Smith, Jr.
Date: Nov. 1963



