MAXWELL AVE.

BENNETT AVE.

BLVD. ORIENTA

GLENN AVE.

18 ORIENTA

PARK 3 ADDITION

SAVANNAH AVE.

35.16 FLD. IN
36.66 FLD. OUT

35.43 FLD. OUT

TO FIELD ENGINEER'S CHECK STORM WATER SEWER FOR CLEARANCE

Plan Scale 1"=40'
Profile Scale 1"=40' Hor. 1"=4 Vertical

3A. 39.77 E. Rm M.H. N.S. Bennett Midway Bet. Savannah & Maxwell

N.Ch. Savannah 7 S.Ch. Maxwell 7

Natural Ground 7

Sand Fill Sta 0+05 To Sta 0+65

Manhole Sta 0+00 Inv. 87.10

Manhole Sta 2+52 Inv. 91.30

Manhole Sta 5+12 Inv. 92.50

Manhole Sta 7+92 Inv. 93.30

Manhole Sta 10+69 Inv. 94.07

Manhole Sta 12+90 Inv. 94.28

Manhole Sta 0+05 Inv. 92.10

92.50 FLD.

93.01 FLD.

33.50 FLD.

94.00

94.28 FLD.

92.10 FLD. IN.
NOTE: CONSTRUCT INTERIOR DROP TO WITHIN 6' OF M.H. FLOW. SEE DETAIL SHEET.

85.88 Out

1290 LIN. FT. 8" V.C.P. @ 0.2 % GRADE

1290 LIN. FT. 8" V.C.P. @ 0.2 % GRADE

Lat. 21 Sub. 3 San. Sewer 22
City Of Wichita, Kansas
B.E. Smith, City Engineer
Proj. No. C26-83 Date- JUNE, 1955