GEN ERAL NOTES

1. All services to be City of Tucson standard.
2. Sewer main to be constructed by the Department of Public Works Section.
3. All services & easements shall be constructed in accordance with City of Tucson Specifications for Public Improvements.
4. Sanitary sewer manhole diameter shall be 4'-0" min. for depth to 10' and 5' min. for depth 10' to 15'. Manholes deeper than 15' require special design.

SANDPLUM

LANE

MULBERRY PLACE

Sta 8+10.00 Const. Mh Conf. Type A

Sta 7+83.00 Const. Mh Conf. Type A

Sta 10+00.00 Const. Mh Conf. Type A

Note: Engr's Stub from Col. Book E pg.

Existing 10' San. Sewer Easement

Note: Ref. Location of end of dirt & rock fill from Conf. as built plans

Existing 14" Concrete Block

Sta 7+83.00

Existing 10' San. Sewer Easement

8" Sewer

8" Sewer

8" Sewer

8" Sewer

8" Sewer

House

House

House

13"

14"

10"

10 Elm

8 Elm

6 Elm

24 Elm

30 Elm

18 Elm

Existing 8" Sewer

8" Sewer

8" Sewer

8" Sewer

8" Sewer