FOURTH FINANCIAL GARAGE
EBY JOB #572

TRANSMITTAL OF DRAWINGS, DATA AND SAMPLES
FOURTH FINANCIAL CENTER
WICHITA, KANSAS

TO: City of Wichita
Attention: Dick Lynn

Date: 5-16-74

Submittal No. _____

We enclose the following:

No. of Copies	Spec Para.	Supplier's Number	Supplier	SOM #	Sub-mission	Description	Action Code
1 print		KG-1	Kendall, Inc.			Underground Piping	

Per your request.

/ / Please return (4) four prints of all approved sepia.

/ / Please revise and resubmit C Action or B Action resubmit.

A Action - Proceed
B Action - Proceed as Noted
C Action - Resubmit

MARTIN K. EBY CONSTRUCTION CO., INC.
P.O. Box 725 , Wichita, Ks. 67201

By: Ed Cooper
Ed Cooper, Project Engineer

STORAGE ROOM
FL. EL. 104'-7½"

FLUSH FLOOR

4" DRAIN
INV. EL. 101.2

8" ø CAST SLEEVE
INV. EL. 101'-3½"

INV EL. 101'-8"

3" C.I.

DROP

INV EL. 101'-0

INV EL. 97'-5"

3" EF-B. - RIM EL 98-8½"

INV EL. 96'-3"

3'-0" ø FIBERGLASS SUMP x 6'0" DEEP

7'-0"

DIR-1 DRAIN
RIM EL 103'-2

3'-0"

3" CLEAN OUT

INV EL. 103'-2

3" CLEAN OUT
FLUSH FLOOR

CEILING HUNG FAN
COIL UNIT EL 103

CEILING HUNG DRAIN
FOR COND. SEE DWG. KG-2

CEILING HUNG DRAIN
WATER - FOR COND.
SEE DWG. KG-3

3" XH C.I. WALL SLEEVE
INV. EL. 106'-4"

2½" CW - INV. EL. 106'-4⅝"

MECH ROOM B4
FL. EL. 98'-9½"

WALL SLEEVE

4" SCH 40 WALL SLV.
INV. EL. 106'-11"

C.O. IN WALL

6" SCH 40 WALL SLEEVE
INV. EL. 106'-4"

INV. EL. 106'-11½"

THRUST BLOCK

8'-0"

6"

NEW CATCH BASIN
BY CITY

IE 107.16

ENCASED CONDUIT

SEE DETAIL "B"
THIS SHEET

C.O.

6" IE 106.33
CONNECT TO STUB
6" IN EXISTING PIP.

NEW STORM INLET
BY CITY

IE 107.85

12" STORM

INV. EL. 105.10

INV. EL. 106.30

CURB LINE

2'X8' INLET BY G.C.
SEE GP-5 FOR DETAIL

SEE DETAIL "A" THIS SHEET

EXISTING 6" VALVE BOX

D.I.-1 RIM EL 110'-2"

4" STORM

INV. EL. 108.70

INV. EL. 108.70

ENCASE IN CONCRETE
SEE GP-5 FOR DETAIL

SEE GS-2 & GP-5
FOR DIR. DETAILS

TERMINATE WITH FLANGE
6" INSIDE VAULT

WATER METER VAULT
PER CITY OF WICHITA
STANDARDS - BY G.C.
SEE DETAIL ON GP-5
CO-ORDINATE WITH
WICHITA WATER DEPT

This Drawing Submitted
For Approval 4-30-71
Date

SEE FIELD INSTRUCTION #10
FOR INSTALLATION OF SLEEVES

12" STORM

12" SAW

6X4 INCREASER

ENCASED CONDUIT

4" B&S X H

EMPTY

4" C.I. OFFSETS

COMB. WYE & 1/8

FLUSH TO
IN SIDE

DETAIL "B" - SCALE 1/2" = 1'-0"

KENDALL INC.