



PLAN	DATE
DESIGNED BY	
CHECKED BY	
IN CHARGE BY	
DATE	




PROFILE	DATE
DESIGNED BY	
CHECKED BY	
IN CHARGE BY	
DATE	




AVAILABLE FROM THE BEST
FILMED COPY


STANDARD MANHOLE, TYPE "C"



DROP MANHOLE, TYPE "C"



OUTSIDE DROP MANHOLE, TYPE "C"



GENERAL NOTES

MORTAR USED IN MASONRY CONSTRUCTION SHALL CONTAIN 8 BAGS OF CEMENT PER CUBIC YARD.

STANDARD MANHOLES TYPE "C" AND STANDARD DROP MANHOLES TYPE "C" SHALL BE BID AS STANDARD MANHOLES FOR THE TYPE AND DIAMETER INDICATED.


OUTSIDE DROP MANHOLES TYPE "C" SHALL BE BID AS STANDARD OUTSIDE DROP MANHOLES FOR THE TYPE AND DIAMETER INDICATED. ALL MANHOLE DIAMETERS WILL BE 4 FT. UNLESS INDICATED OTHERWISE. MANHOLES WITH PIPE SIZES LARGER THAN 24" SHALL BE 3 FT. DIAMETER.

THE FLOORS OF ALL MANHOLES SHALL BE SHAPED TO INCREASE HYDRAULIC EFFICIENCY USING 8 BAGS SAND MIX CONCRETE.

CAST IN PLACE CIRCULAR CONCRETE MANHOLES ARE TO BE CONSTRUCTED ONLY ON SEWERS NOT SUBJECT TO DETECTION OF CONCRETE DUE TO FORMATION OF HYDROGEN SULFIDE GAS AND IN LOCATIONS WHERE IT IS OBVIOUS THAT THE SETTLEMENT OF THE MANHOLE JOINT WHICH MAY BE NECESSARY, WILL NOT REQUIRE MODIFICATION OF THE CONCRETE BARREL.


PIPES INSTALLED WITHIN THE MANHOLE EXCAVATION SHALL BE CRADLED WITH CONCRETE TO THE LIMITS OF THE MANHOLE EXCAVATION. COST OF CRADLE WITHIN MANHOLE EXCAVATION SHALL BE INCLUDED IN THE PRICE BID FOR THE MANHOLE.

NOTE: REINFORCING STEEL SHALL BE INSTALLED IN THE MANHOLE BASES 6" ABOVE THE BOTTOM. REINFORCING STEEL SHALL CONSIST OF NO. 4 BARS PLACED ON 6" CENTERS IN BOTH DIRECTIONS. THE COST OF REINFORCING STEEL IS TO BE INCLUDED IN THE PRICE BID FOR THE MANHOLE.




SECTIONAL ELEVATION-INVERT


NOTE: OPENING FOR INLET PIPE CUT IN MANHOLE WALL AND PIPE GROUTED IN PLACE WITH NON-SHRINKING GROUT. EXTERIOR OF COMPLETED CONNECTION TO BE SEALED WITH APPROVED COATING.




MANHOLE COVER




MANHOLE COVER



MANHOLE COVER



MANHOLE RING



MANHOLE RING

488-76-248-80863-000-000-008

REVISED 5-18-77

DETAILS OF
SEWER APPURTENANCES
ADDED AS STANDARD DESIGN
BY
ENGINEERING DIVISION
CITY OF WICHITA, KANSAS
R. W. LINN CITY ENGINEER
1974

GREAT PLAINS INDUSTRIES, INC. SHT. 6 OF 8

AVAILABLE COPY... FILMED FROM THE BEST

