Const Drop Inlet with 18" Sluice Gate (ARMCO Model 20-10C or Equal) See Detail Rt.

60 L.F. Conc Flume See Detail Rt.

Const Conc Headwall with 18" Flapgate (ARMCO Model 10C or Equal), F.F. El Conc or Stone Riprap

Install 265 L.F. 18" Pipe

Western Iron & Found. Frame 400F & Grate 400G or equal

18" Sluice Gate (Armco Model 20-10C or equal)

DROP INLET DETAILS

STORM SEWER PROFILE
Scale: Hor 1"=50'
Ver. 1"=5'

Remove Exist. Inlet & Const New Type 1A Inlet with 4 L.F. 15" RCP Extension of Exist Storm Sewer

Ex. 30" Storm Sewer

PLOT PLAN
1" = 20'

B & H ADDITION

APPROVED AS NOTED
BY CITY ENGINEER OF WICHITA
Sanitary Sewers
Storm Sewers
Driveway Approaches

NOTE TO CONTRACTOR
This project will be constructed under the supervision of the CITY ENGINEER and conforming to the STANDARDS of the CITY OF WICHITA. CONTRACTOR will notify the City of Wichita for all inspections required and inspected.

Approved drainage plan & site grading to be inspected by Maintenance

8-3-78

CONC FLUME DETAILS

Approved for final Permit
9/12/78

Revised 9-8-78 (JSC)

1/3

FILMED FROM THE BEST AVAILABLE COPY

10-11-78

APPROVED AS NOTED
By CITY ENGINEER OF WICHITA
Sanitary Sewers BLF
Storm Sewers
Driveway Approaches

NOTE TO CONTRACTOR

This project will be constructed under the supervision of the CITY ENGINEER and conformity to the SPECIFICATIONS of the CITY OF WICHITA. The CONTRACTOR will reimburse the City of Wichita for all cost of ~~Engineering, Layout, and~~ Inspection.

Sta. 1+39 Const. Std. Type (A) or "C" Manhole with 2-4" Stubs NW & NE

Sta 1+30.7 Const. Std. Type (A) or "C" Manhole with 2-4" Stubs NW & NE

E & W

E & W

1+39

DROP INLET BOX

CONC. FLUME

440.0'

52.42'

80.80'

59.0'

16.0'

12.0'

37.0'

81.39'

425.0'

106.6'

54.37'

SETBACK LINE

SETBACK LINE

"A-1"

"A-2"

"B"

"C"

"D"

"A"

1-6" CICL MJ 45° Bend

1-6" CICL MJ 90° Bend

61'-6" AC Pipe

162'-6" AC Pipe

10' Water Esmt.

TYP. CONC. DRIVE & CONC. SLAB W/ CURB 18" WIDE HIGH

Exist. Sewer

1-6" CICL MJ 45° Bend

20' Utility Esmt.

160'-6" AC Pipe

LINE 1

LINE 2

100'-6" AC Pipe

20' Utility Esmt.

20' Utility Esmt.

SETBACK LINE

EAST 8" SAN SEWER

410.0'

15' UTILITY EASEMENT

1-6" CICL MJ Cap Tapped 2" 1-2" Blow Off Assy.

CONCRETE APPROACH

CONCRETE APPROACH

Sta. 0+00- Const. Std. Type (A) or "C" Manhole on Exist. 8" Sewer.

FLUME

Sta. 0+00- Connect to Exist. Manhole Reshape Invert

48'-15" Steel Casing Pipe

15" RCP

15" RCP

℄ OF DOUGLAS AVE.

EXISTING 24" RCP STORM

EXIST. 30" RCP STORM

EXISTING 8" WATER LINE

1-8"x6" CIMJ Tapping Sleeve
1-6" Tapping Valve
1-6" Valve Box

Remove & Replace 7 S.Y. Exist. Pvmt. & 7 L.F. Curb & Gutter

UTILITIES PLAN 1"=20'

LOT 2 OF B&H ADDITION & 40' EAST PART OF THE NW¼ SECTION 20, T27S, R2E

PRIVATE PROJECT

for 8/29/79

B.M.- Brass cap NE Hub Guard on Bridge E. of Property El. 159.71

Sta 0+00 Const. Std. Type (A) or "C" Manhole on Exist. 8" Sewer Top El. 155.55

Ex. Ground

139 L.F. 8" VCP or ABS @ +0.40%

155

150

145

℄ in 145.00
℄ out 144.90 (Ex.)

℄ in 145.87
℄ out 145.54

LINE 1

Scale: Hor. 1"=50'
Ver. 1"=5'

Sta 0+00- Const. Std. Type (A) or "C" Manhole on Exist. 8" Sewer El. 151.55

Sta 1+30.7 Const. Std. Type (A) or "C" Manhole with 2-4" Stubs NW & NE Top El. 154.5

Fin. Grade

Ex.

131 L.F. 8" VCP or ABS @ +0.66%

150

145

140

℄ in 140.80
℄ out 140.70 (Ex.)

℄ in 141.99
℄ out 141.66

LINE 2

Only Sanitary Sewer Line 2 has been reviewed by Frank Jenkins

Frank E. Jenkins P.E.

APPROVED
WICHITA WATER DEPARTMENT
CITY OF WICHITA
10-10-78

LOT 2 - B. & H. ADDITION
SITE DEVELOPMENT-UTILITIES

CITY SAN. SEWER PROJ. 468-76-245-80529-000-000-008

CITY WATER PROJ. 5a1-80-925-80463-000-000-001

ADDRESS - 8202 E. DOUGLAS

San. Sewer Revised - 12-28-78 (JEL)

LOT 2 - B & H ADDITION

SITE DEVELOPMENT-UTILITIES

SITE PLAN