WL Sta. 00+00.00 Line 1
BL Sta. 12+29.85 03.99 Lt
#1-8"x6" Tapping Sleeve
#1-6" Tapping Valve CLOW
#1-6" Valve Box
Valve Box Elev. =1398.00
*To be Installed by COW
*To be Paid by Contractor

Prop 2" Dom WL

WL Sta. 00+28.81 Line 1
BL Sta. 12+29.85 24.90 Rt
Backflow in Building

Fire Dept. Hook-up

End of COW Maintenance

Port of Lot 2

1215

13+00

12+00

Prop Building

15' Building Setback

20' Utility Easement

Property Line

Exist Water Line

Exist Fire Hydrant

SS

Parcel #2

Vert. Scale
(IN FEET)
1 inch = 5 ft.

(IN FEET)
1 inch = 20 ft.

8"x6" Tapping Sleeve

Backflow in Building

Ground

28.89 LF of 6" WL

6" Top = 1398.00

6" Top = 1398.00 +28.89

1410

1400

1390

0+00

Retail Center at Northrock
Fire Line
Wichita, Kansas

PROJECT NUMBER

kemiller engineering
516 S. Market, Wichita, KS 67202 316/264-0242

KEM NO.	FILE	DATE	SHEET
08097	ppw	06/2008	2
DESIGN	DRAWN	REVISED	OF
KM	KLM		3