



* PRIOR TO BEGINNING CONSTRUCTION, THE CONTRACTOR SHALL EXCAVATE THE EXISTING 24" WATERLINE NO. 3 STATION 14+38.88 TO VERIFY PIPE SIZE, TYPE, FITTINGS AND HORIZONTAL AND VERTICAL LOCATION. THE CONTRACTOR SHALL REPORT HIS FINDINGS TO THE ENGINEER SO MATERIALS NECESSARY TO COMPLETE THE CONSTRUCTION SHALL BE PROVIDED SEPARATELY TO THE PROJECT.

PLAN:
SCALE: 1"=20'
PROFILE:
SCALE: 1"=20' (HORIZ.)
SCALE: 1"=2' (VERT.)

Station	Elevation	Description
1292.00	+38.86	END WATERLINE NO. 3 12" X 22 1/2" BEND
1292.04	+25.57	12" X 11 1/4" BEND
1292.12		
1292.27		
1292.42		EXIST. 36" RCP TO BE REMOVED
1292.58		
1292.73		
1292.77	+88.30	12" X 12" TEE
1292.88		PROP. 9" X 5" RCP
1292.98	+18.30	PROP. 12" WATERLINE
1293.04		PROP. 48" WATERLINE
1293.19		
1293.26	+25.04	12" X 11 1/4" BEND
1293.29	+16.00	12" X 22 1/2" BEND
1293.84 (24")		24" X 12" TAPPING SLEEVE BEGIN WATERLINE NO. 3
1293.34 (12")		

Job No.	W/2.3
Date	05-30-06
Drawn	7
Checked	60 of 96

1	5.30.06	BID SET
2	4.27.06	FIELD CHECK SET

Mark	Date	Description

WICHITA WATERWALK

PUBLIC IMPROVEMENTS PACKAGE 2 PHASE 2

Johnson & Associates, Inc.
100 E. California Ave., Third Floor
Oklahoma City, OK 73104
(405) 235-8173 FAX (405) 235-8078
Certificate of Authorization RE-1728 EXP. DATE: 12/31/2006

Gossell Livingston
Architecture
Wichita, KS 67202
Tel: (316) 265-4387
Fax: (316) 265-5646
Email: gossell@gl.com

© 2006 Gossell Livingston Associates, Inc.
The drawing and all information herein is the exclusive property of Gossell Livingston Associates, Inc. and is not to be copied or used in any way without the express written consent of Gossell Livingston Associates, Inc. All drawings are prepared and reproduced under the supervision of a Professional Engineer.

ACAD FILE: H:\2215\2215 Ph 2\2215012-WATER.dwg, 5/29/2006 2:03 PM, Peter Borelli
PLOT: 5/29/2006 2:03 PM