



Areas of soft existing ground that need to be overexcavated are indicated by:

These areas need to be overexcavated to a minimum depth of 300mm, backfilled, and compacted before placing any fill above the area.



PROJECT NUMBER 472-83863		SHEET NAME XSEC11		ENGINEERING DIRECTORY F:\29th North\Earth\dwg	
DESIGN TPV	DRAWN TPV	APPROVED JFB	DATE Oct. 2004	SCALE 1:100	BAUGHMAN NO 02-02-E232

CAPITAL IMPROVEMENT PROJECT  
**29th STREET NORTH CROSS SECTIONS**

**BAUGHMAN COMPANY, P.A.**  
ENGINEERING, SURVEYING, & PLANNING  
316-262-7271 • 315 ELLIS • WICHITA, KANSAS 67211