


Note:  
S3 bars omitted unless grade box or slab thickness is greater than or equal to 12".

Note:  
F3 bars omitted unless floor thickness is greater than or equal to 12".

†† Omit S5 bars when S3 bars are omitted and omit the bottom layer of F4 bars when F3 bars are omitted.

See Standard No. RD 080 for additional details.



TYPICAL SECTION

GENERAL NOTES

**LOADING:** HS20-44 AASHTO Specifications, 1983 Edition.

**UNIT STRESSES:** Grade 4.0 Concrete;  $f'c = 4,000$  p.s.i.  
Reinforcing Steel;  $f_y = 60,000$  p.s.i.

**FILL HEIGHT:** Unless otherwise noted, the Design Fill Height is measured from the riding surface at the culvert and shall include the surfacing.

**CONCRETE:** Grade 4.0 Concrete shall be used throughout. Bevel all exposed edges with a 3/4 inch triangular moulding. Where Grade 4.0 Concrete (AE) is specified, it shall be placed in the top slab above the Construction Joint.

**REINFORCING:** All reinforcing shall conform to ASTM A615, Grade 60. All dimensions relative to reinforcing steel shall be to centerline of bar unless otherwise noted.

**EXCAVATION:** Excavation for culverts less than bridge length shall not be paid for directly but shall be subsidiary to Grade 4.0 Concrete. Excavation for RCB Bridges shall be paid for as Class III Excavation.

**SEAL COURSE:** A Seal Course may be required by the Engineer. The Seal Course shall be unreinforced Concrete (Commercial Grade) to a minimum depth of 3 inches or as determined by the Engineer. Concrete for the seal course shall be paid for at the unit price set for Concrete for Seal Course.

**FOUNDATION STABILIZATION:** Foundation Stabilization may be required as directed by the Engineer. The depth of Foundation Stabilization shall be determined by the Engineer. Foundation Stabilization shall be paid for at the determined Unit Price set for Foundation Stabilization. See Auxiliary Details.

**QUANTITIES:** The quantities shown in the Culvert Summary include apron and/or soil saver quantities when their construction is required by the plans. Payment for additional quantities that result from including seal course and/or floating apron, as a change in original plans, shall be made at the Unit Price bid for the various items involved.

**GRANULAR BACKFILL (WINGWALLS):** Special backfill procedures may be required at the direction of the Engineer. See Auxiliary Details Sheet.

**STRIKE LINE:** Wingwalls and that portion of the RCB outside the Strike Line shall be constructed level. Footing for wingwalls shall be constructed with the culvert floor. See wingwall detail sheet.

PLAN

CULVERT SUMMARY												
Flow Line Elev.	Crown Gr. Elev.	Design Fill Ht.	Skew	Wings	Scour Apron	Soil Saver	Concrete			Reinf. Steel (Gr. 60)		
							Barrel (Cu.Yds.)	Wings (Cu.Yds.)	Total (Cu.Yds.)	Barrel (Lbs.)	Wings (Lbs.)	Total (Lbs.)
Ext.Lt. 154.66	159.50	2	0	FLARED	YES	NO	93.97	3.71	97.68	11637	290	11927
Ext.Rt. 154.83				NONE			0.00	0.00	0.00	0	0	0

Minimum Splice Lengths	
#4	1'-4"
#5	1'-8"
#6	2'-0"

BAR SCHEDULE																											
F1		F3				F4			S1				S3			S4		S5									
Size	Spa.	No.	Length	Size	Spa.	No.	Length	Size	No.	Length	Size	Spa.	No.	Length	Size	Spa.	No.	Length	Size	No.	Length	Size	Spa.	No.	Length		
Ext.Lt.	6	6"	296	8'-8"	N/A	N/A	N/A	N/A	N/A	N/A	4	28	37'-6"	6	6"	309	8'-8"	N/A	N/A	N/A	N/A	5	27	52'-0"	N/A	N/A	N/A
Ext.Rt.	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

SUMMARY OF QUANTITIES	
Concrete (Grade 4.0)	99.4 C.Y.
Concrete (Grade 4.0)(AE)	0.0 C.Y.
Reinforcing Steel (Gr. 60)	11950 Lbs.
Reinforcing Steel (Epoxy Coated)	0 Lbs.
Class III Excavation	C.Y.
Foundation Stabilization (Set)	1 C.Y.
Concrete for Seal Course (Set)	1 C.Y.
Granular Backfill (Wingwalls) (Set)	1 C.Y.

NO.	DATE	REVISIONS	BY	APP'D
KANSAS DEPARTMENT OF TRANSPORTATION				
SINGLE 8 ft x 3 ft RCB 152.8 ft EXT. LT.				
BR 1.8.3 P		Sedgwick Co.		
FHWA APPROVAL	6-5-91 APP'D	KENNETH F. HURST		
DESIGNED	DETAILED	QUANTITIES	TRACED	
DESIGN CK.	DETAL CK.	QUAN. CK.	TRACE CK.	