

ENGINEERING DEPARTMENT

CITY OF WICHITA

MISCELLANEOUS INFORMATION

Signed

Spencer Cody

Contractor

Cornejo + Sons.

Date

12-02-09

Project

Zoo park Circle - Cox Machine 3rd Addition

Project Number

472-84820

The base lift of asphalt was defective from station St 20.0
to station St 50.0 on the West half of the roadway. The defective
asphalt was removed and replaced. The remaining portion of
the project was completed as specified per plan.