ENGINEERING DEPARTMENT | CITY OF WICHITA | MISCELLANEOUS INFORMATION

Signed Spencer Cooley | Contractor Cornejo & Sons. | Date 12-02-09

Project Zoo Park Circle - Cox Machine 3rd Addition

Project Number 472-84820

The base lift of asphalt was defective from station 5+20.0 to station 6+50.0 on the West half of the roadway. The defective asphalt was removed and replaced. The remaining portion of the projet was completed as specified per plan.

Form 192-034 (4/81)