



N



**SITE 2**



N GILMAN AVE

N SPAULDING AVE

N

447

831

802

805

431

430

429

432

## Video Inspection Master Report

5/10/2012  
8:12 AM

US Structure: 5448-447      831 N SPAULDING AVE      Date Insp.: 4/11/2012      Basin: C03E  
 DS Structure: 5448-430      1116 W MURDOCK ST      Dir Televised:      Upstream To Downstream

### Pipe Information

Shape: Round      Length Status:      Project No. : B-214  
 Dia/Ht: 8      Material: VCP      Index:  
 Length: 336.9      Slope: 0.002      DVD #0706

Obs. #	VTR	Counter	Distance	Location	Description	Rating	Ratings		
							Obsrvd (gpm)	Est. (gpm)	Struct Clean
1			0.0		US Manhole	1			
2			18.1		Sealed Off Wye	1			
3			18.9		Crack-Radial	3			
4			20.7		Sealed Off Wye	1			
5			21.7		Broken Pipe	2			
6			41.3		Sealed Off Wye	1			
7			42.1		Crack-Radial	2			
8			43.9	825 N SPAULDING	Wye Service	1			
9			45.0		Crack-Radial	1			
10			66.0	844 N GILMAN	Break-In Conn	1			
11			68.4	821 N SPAULDING / roots	Break-In Conn	1			
12			72.8		Roots	1			
13			77.5	821 N SPAULDING	Break-In Conn	1			
14			78.1		Roots	2			
15			80.3		Roots	1			
16			83.0		Roots	1			
17			94.7	840 N GILMAN / roots	Wye Service	2			
18			96.9		Sealed Off Wye	1			
19			111.5		Observation Hole	1			
20			120.5		Sealed Off Wye	1			
21			122.8		Sealed Off Wye	1			
22			131.5		Crack-Radial	1			
23			146.3	840 N GILMAN	Wye Service	1			
24			147.3		Crack-Radial	2			
25			148.2		Sealed Off Wye	1			
26			164.8		Crack-Radial	3			
27			167.4		Crack-Radial	1			
28			173.9		Sealed Off Wye	1			
29			188.1		Crack-Radial	3			
30			191.0		Crack-Radial	2			
31			195.0	834 N GILMAN	Wye Service	1			

## Video Inspection Master Report

5/10/2012  
8:12 AM

US Structure: 5448-447      831 N SPAULDING AVE      Date Insp: 4/11/2012      Basin: C03E  
 DS Structure: 5448-430      1116 W MURDOCK ST      Dir Televised:      Upstream To Downstream

32	197.5		Sealed Off Wye	1	
33	200.7		Crack-Radial	2	(grease marks at ¾ tile due to sag ahead)
34	203.4		Crack-Radial	2	
35	218.0		Sealed Off Wye	1	
36	220.5	815 N SPAULDING	Wye Service	1	
37	224.5		Observation Hole	1	
38	241.3		Mat. Chngs to PVC	1	
39	243.8	828 N GILMAN / PVC	Break-In Conn	1	
40	245.5		Grease bridge on crown where PVC meets VCP	3	
41	245.5		Mat. Chngs to VCP	1	
42	250.0		Broken Pipe	4	
43	266.9		Sealed Off Wye	1	
44	269.3	811 N SPAULDING	Wye Service	1	
45	288.6	809 N SPAULDING / PVC	Break-In Conn	1	
46	294.6		Sealed Off Wye	1	
47	319.9	822 N GILMAN	Wye Service	1	
48	322.1		Sealed Off Wye	1	
49	336.0	1110 W MURDOCK	5448-430 DS Manhole	1	

The upstream 200 ft is on grade, but from 200' to 300' water is over the camera most of the way / needs open cut to correct grade:

Pulled back to record sags:

50	235.5		Sag	1	
51	235.5		Sag	1	
52	242.8		Sag	1	
53	245.3		Sag	5	
54	299.7		Sag	1	
55	299.7		Sag	1	
56	148.8		Sag	1	
57	155.9		Sag	4	
58	161.8		Sag	1	
59	161.9		Sag	1	
60	178.7		Sag	3	
61	178.8		Sag	5	