



U.S. Patent No. 6,951,619

Dimensions in inches

Permanent Pool Volume = 800 US gallons

The Hydroguard must be cleaned after the construction period if it is used as a sediment and erosion control measure

The Hydroguard should be inspected once per year for stabilized sites

Inspection will determine the maintenance frequency (annual maintenance or once every two years typical for stabilized sites)

Sites with unstable conditions (exposed soil or materials storage) will require more frequent inspection and maintenance

Hydroworks, LLC
 50 S. 21st St., Kenilworth, NJ 07033
 Phone: 888-290-7900 Fax: 888-783-7271
 Web: www.hydroworks.com

Sheet 3 of 4

Hydroworks HG5 (60"Ø)

PROJECT:

LOCATION:

REVISION DATE: 02/10/2011

