


N 21575.15 E 20595.04  
 STA. 0+00.00 SWS LINE 2  
 BL STA. 32+40.06, 226.81' RT  
 PLACE 15" RCP END SECTION &  
 17 SY LIGHT STONE RIP RAP  
 FL ELEV.=1309.00

CONTRACTOR TO RESTRAIN LAST THREE  
 SECTIONS OF PIPE AND END SECTION AND  
 FIELD ADJUST END SECTION TO MATCH  
 SLOPE

N 21369.01 E 20597.55  
 STA. 2+06.16 SWS LINE 2  
 BL STA. 32+37.55, 20.67' RT  
 CONSTRUCT TYPE 1A 10'x3' INLET  
 W/ 24" SNOUT & STAINLESS  
 TRASHSCREEN FILTER

N 21327.67 E 20600.06  
 STA. 2+47.57 SWS LINE 2  
 BL STA. 32+35.05, 20.67' LT.  
 CONSTRUCT TYPE 1A 5'x3' INLET

REMOVE EXISTING TREES AS NECESSARY  
 FOR CONSTRUCTION. SUBSIDIARY TO  
 BID ITEM FOR "SITE CLEARING".



**Emerald Bay Estates  
 Second Addition**

30 ①

SHORELINE

32+00


Future AC Pavement

64'R/W

Future 8" SS

31

3'



Ruggles & Bolin, P.A. Engineering & Surveying, Land Planning 624 North Main Wichita, Kansas 67203 www.ruggles.com (316) 264-4600 Email: info@ruggles.com	PROJECT NUMBER <b>468-84845</b> DRAWING FILE ENGINEERING BASE (SWS Line 1)
DESIGN <b>AML</b> UTILITY	DRAWN <b>RA</b> DATE <b>October 8, 2012</b>
<b>STORM SEWER IMPROVEMENTS          LINE 2          WICHITA, KANSAS</b>	
REVISION REVIEW REVIEW	SHEET <b>3</b> OF <b>13</b>