



U.S. Patent No. 6,951,619

Dimensions in inches

Permanent Pool Volume = 800 US gallons

The Hydroguard must be cleaned after the construction period if it is used as a sediment and erosion control measure. The Hydroguard should be inspected once per year for stabilized sites.

Inspection will determine the maintenance frequency (annual maintenance or once every two years typical for stabilized sites).

Sites with unstable conditions (exposed soil or materials storage) will require more frequent inspection and maintenance.

Hydroworks, LLC

50 S. 21st St., Kenilworth, NJ 07033

Phone: 888-290-7900 Fax: 888-783-7271

Web: www.hydroworks.com

Hydroworks HG5 (60"Ø)

PROJECT:

LOCATION:

REVISION DATE: 02/10/2011



WATER QUALITY INLET DETAIL



RUGGLES & BOHM
 ENGINEERING | SURVEYING | LANDSCAPE ARCHITECTURE | GOVERNMENT
 824 NORTH MAIN WICHITA, KANSAS 67203 P (316) 264-8008 F (316) 264-4821
 WWW.RUGGLESANDBOHM.COM
 PROJECT NUMBER: 472-8507B R/S JOB NO.: 4057E DWG. SCALE:
 DRAWING FILE: ENG BASE {WQ DETAIL}

DATE: June 25, 2013
 DESIGN:
 DRAWN:
 REVIEW:
 SHEET: 18
 OF: 45