



U.S. Patent No. 6,951,619

Dimensions in inches
 Permanent Pool Volume = 2500 US gallons
 The Hydroguard must be cleaned after the construction period if it is used as a sediment and erosion control measure.
 The Hydroguard should be inspected once per year for stabilized sites. Inspection will determine the maintenance frequency (annual maintenance or once every two years typical for stabilized sites).
 Sites with unstable conditions (exposed soil or materials storage) will require more frequent inspection and maintenance.

Hydroworks, LLC
 50 S. 21st St., Kenilworth, NJ 07033
 Phone: 888-290-7900 Fax: 888-783-7271
 Web: www.hydroworks.com

Hydroworks HG8 (96" ϕ)

PROJECT:

LOCATION:

REVISION DATE: 01/09/2009



B Baughman		Huntington Park Addition HG 7 Details Sanitary Sewer Improvements	
<small>Baughman Company, P.A. 315 Ellis St. Wichita, KS 67211 P 316-262-7271 F 316-262-0149 ENGINEERING SURVEYING PLANNING LANDSCAPE ARCHITECTURE</small>			
PROJECT NUMBER 468-84884	DESIGN PAT	DRAWN JAK	DATE 7/15/13
REVISIONS:	APPROVED	SCALE Noted	SHEET 3 OF 12