



1 SECTION
PP2 SCALE 1/2"=1'-0"
0 1 2 3 4

2 SECTION
PP2 SCALE 1/2"=1'-0"
0 1 2 3 4

☒ Indicates where piping or equipment needs to be adequately supported. Supports such as Wall Brackets, Clevis Hangers and Steel or Concrete supports shall be positioned to adequately support the pipe. The Contractor shall also install any additional pipe supports deemed necessary. The Contractor shall submit to the Engineer for approval the type of pipe support and proposed location(s) for installation.

Saved: 07-08-2013 8:49:11 AM by: GJM
 Plot Scale: 1/2"=1'-0" 12:07:31-2013 8:01:40 AM by: GARY LAM
 G:\2011\11123\11123-PP2 Pump Station Sections

		No. _____ Revision _____ By _____ Date _____	
SEDGWICK COUNTY RURAL WATER DISTRICT #1 WATER DISTRIBUTION SYSTEM IMPROVEMENTS BOOSTER PUMP STATION SECTIONS GARY JANZEN, P.E. - CITY ENGINEER CITY OF WICHITA PROJECT NO. 448-90565			
		PROFESSIONAL ENGINEERING CONSULTANTS, P.A. 303 SOUTH TOPEKA WICHITA, KS 67202 316-262-2691 www.pect.com	
Designed by SCU Drawn by CAE	Job No. 34-11123 Date JULY 2013	Sht. PP2 of 24	