



Transmittal Form Chain of Custody New Main/Construction Water Quality Report

1 of 2

Wichita Public Works & Utilities
Production and Pumping Division
Wichita Municipal Water & Wastewater Laboratory E-60603
Phone # 316-269-4770/4771
Fax # 316-269-4772

APPROVED BY: TM 7-6-16
OF SAMPLES: 2 RECEIPT #: 122808

Project Location: 2660 E. Greenleaf Ct Contractor: CK contracting
Project Number: PPW 0373 1972ppw Contractor phone #: 316-267-1996
OCA Number: 607853 Contractor fax #: 316-267-2786
Sample Collector: Blake Henry Contractor email: T.Henry@ckcontractingllc.com

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
7-26	1:23	line-1	BWO 3089	FAIL	0.22	Low Cl ₂
7-26	1:23	fire line.	BWO 3090	FAIL	0.21	Low Cl ₂

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: Blake Henry Date & time 7-26-16 1:23

CUSTODY RECORD	DATE	TIME	DATE	TIME
Relinquished by:			Received by: <u>Paul Mills</u>	7/26/16 1401
Print Name:			Print Name: <u>PAUL MILLS</u>	
Relinquished by:			Received by:	
Print Name:			Print Name:	

Results Submitted by: Bill A Justice Date: 7/26/16
(over)