



CITY OF WICHITA

# Transmittal Form Chain of Custody New Main/Construction Water Quality Report

1 of 3

Wichita Public Works & Utilities  
Production and Pumping Division  
Wichita Municipal Water & Wastewater Laboratory E-60603  
Phone # 316-269-4770/4771  
Fax # 316-269-4772

APPROVED BY: <u>Tm 9-20-16</u>
# OF SAMPLES: <u>1</u> RECEIPT #: <u>122822</u>

Project Location: La Quinta Contractor: CK Contracting  
 Project Number: PPW. 1972 Contractor phone #: 316-267-1996  
 OCA Number: 607853 Contractor fax #: 316-267-2786  
 Sample Collector: Terry Henry Contractor email: T.Henry@ckcontracting.com

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl <sub>2</sub>	Comment
9-20	11:31	Line # 1	BWO 3955	PASS	2.77	
9-20	11:35	FIRE LINE	BWO 3956	PASS	2.78	

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature:  Date & time 9-20-16 - 11:36

CUSTODY RECORD		DATE	TIME	DATE	TIME
Relinquished by:	<u></u>	9-20	12:10	Received by:	<u></u>
Print Name:	<u>Terry Henry</u>			Print Name:	<u>PAUL MILLS</u>
Relinquished by:				Received by:	
Print Name:				Print Name:	

Results Submitted by:  Date: 9/21/16  
(over)