



Transmittal Form Chain of Custody New Main/Construction Water Quality Report

Wichita Public Works & Utilities
 Production and Pumping Division
 Wichita Municipal Water & Wastewater Laboratory E-60603
 Phone # 316-269-4770/4771
 Fax # 316-269-4772

APPROVED BY: TM 9-20-16
 # OF SAMPLES: 1 RECEIPT #: 122823

Project Location: 6500 W. Central Ave. Wichita, KS Contractor: Mies Construction, Inc.
 Project Number: 2004 PPW (Fire Line) Contractor phone #: 316-945-7227
 OCA Number: 607853 Contractor fax #: 316-945-7799
 Sample Collector: GARY KASEL Contractor email: terry@miesconstruction.com

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
9/21/16	12:00 pm	CENTRAL BAY APTS. 6500 W CENTRAL # 1-A <i>(Fire Line)</i>	DWO 3966	Fail	2.69	Total Coliform bacteria present

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: *Gary Kassel* Date & time 9-21-16 12:00

CUSTODY RECORD		DATE	TIME		DATE	TIME
Relinquished by:	<u>Mies Const</u>	9/21/16	12:30 pm	Received by:	9/21/16	12:16 pm
Print Name:	<u>GARY KASEL</u>			Print Name:		
Relinquished by:				Received by:		
Print Name:				Print Name:		

Results Submitted by: *Terry* Date: 9/21/16
(over)