



CITY OF WICHITA

Transmittal Form Chain of Custody New Main/Construction Water Quality Report

Wichita Public Works & Utilities
Production and Pumping Division
Wichita Municipal Water & Wastewater Laboratory E-60603
Phone # 316-269-4770/4771
Fax # 316-269-4772

APPROVED BY: T MASON 9-27-16
OF SAMPLES: 1 RECEIPT #: 122825

Project Location: Central Bay Apartments Contractor: Mies Const
Project Number: ~~40716~~ 2004 Contractor phone #: 316 945-7227
OCA Number: 607853 Contractor fax #: _____
Sample Collector: Tyler DeBorge Contractor email: _____

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
9/27	10:41 AM	Fire line	BWD 4061	Fail	3.24	Total Coliform Bacteria present

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: Tyler DeBorge Date & time 9-27-16 10:41 AM

CUSTODY RECORD	DATE	TIME	DATE	TIME
Relinquished by:			Received by: <u>Matt Jones</u>	9/27/16 11:55
Print Name:			Print Name: <u>Matt Jones</u>	
Relinquished by:			Received by:	
Print Name:			Print Name:	

Results Submitted by: Matt Jones Date: 9/28/16
(over)