



# Transmittal Form Chain of Custody New Main/Construction Water Quality Report

1 of 1

Wichita Public Works & Utilities  
Production and Pumping Division  
Wichita Municipal Water & Wastewater Laboratory E-60603  
Phone # 316-269-4770/4771  
Fax # 316-269-4772

APPROVED BY: <u>BS</u>	<u>10/3/16</u>
# OF SAMPLES: <u>1</u>	RECEIPT #: <u>122829</u>

Project Location: 6500 W. Central Contractor: Mies Construction  
 Project Number: 2004 Contractor phone #: 316-945-7227  
 OCA Number: 607853 Contractor fax #: 316-945-7799  
 Sample Collector: \_\_\_\_\_ Contractor email: terry@miesconstruction.com

**Items in gray are for Lab Use only**

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl <sub>2</sub>	Comment
10-4 16	8:00	<u>Field Line</u> <span style="border: 1px solid red; padding: 2px;">L-1A</span>	<u>BWD</u> 4133	<u>PASS</u>	<u>3.07</u>	

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: [Signature] Date & time 10-4-16-8:00

CUSTODY RECORD		DATE	TIME		DATE	TIME
Relinquished by:	<u>[Signature]</u>	10-4	0835	Received by:	<u>[Signature]</u>	10/4/16
Print Name:		10		Print Name:	<u>CPW</u>	0835
Relinquished by:				Received by:		
Print Name:				Print Name:		

Results Submitted by: [Signature] Date: 10/5/16  
(over)