



## Transmittal Form Chain of Custody New Main/Construction Water Quality Report

Wichita Public Works & Utilities  
 Production and Pumping Division, 1800 Museum Blvd.  
 Wichita Municipal Water & Wastewater Laboratory E-60603  
 Phone # 316-269-4770/4771  
 Fax # 316-269-4772

APPROVED BY: <u>JC</u>
# OF SAMPLES: <u>1</u> RECEIPT #: <u>122895</u>

Project Location: 5339 W 21st N Contractor: Wilks Underground  
 Project Number: 2060 PPW Contractor phone #: 316 640 4326  
 OCA Number: 185009 Contractor fax #: \_\_\_\_\_  
 Sample Collector: Chad Davis Contractor email: Chad@WilksUnderground

**Items in gray are for Lab Use only**

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl <sub>2</sub>	Comment
10-11	7:05 AM	line 1 Hyd	BX0 3980	PASS	2.49	

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: Chad Davis Date & time 10-11 7:05am

CUSTODY RECORD	DATE	TIME	Received by:	DATE	TIME
Relinquished by:			<u>Matt Jones</u>	10/11/17	8:10
Print Name:			<u>Matt Jones</u>		
Relinquished by:			Received by:		
Print Name:			Print Name:		

Results Submitted by: Matt Jones Date: 10/12/17  
 (over)