

SKYWAY IND. PARK
2ND ADDITION 75.00 L.F. 12" F

Sta. 0+00.00, Begin Line 1
1 - 16"x12" Tapping Saddle
1 - 12" Tapping Valve & Valve Box
Tapping saddle, tapping valve & valve
box to be furnished and installed by
the City of Wichita Water Dept.
Final valve elevation
to be set to grade by Contractor.
Valve Box Elev. = 1332.60
N=10,970.31 E=20,045.81

*Proposed
24" SWS
Crossing*

Sta. 0+58.00, End Line 2
1 - Valve Assembly,
Blowoff 2"
Valve Box Elev. = 1336.00
N=10,901.85 E=19,485.36

