

STEEL SCHEDULE


BAR NUMBER	SIZE	b_1										Wt. Lbs.
		a_1	a_2	a_3	#=4'-4"	#=5'-4"	#=6'-4"	#=7'-4"	#=8'-4"	b_2	b_3	
4	#4	4	2	1	3	5	7	9	6	1	1	
		W=4'-4"	5'-7"	6'-7"	4'-0"	6'-1"	-	-	1'-9"	6'-2"	4'-8"	60±
		W=5'-4"	7'-7"	8'-7"	5'-0"	6'-1"	-	-	1'-9"	6'-2"	4'-8"	81±
		W=6'-4"	9'-7"	10'-7"	6'-0"	6'-1"	-	-	1'-9"	6'-2"	4'-8"	101±
		W=7'-4"	11'-7"	12'-7"	7'-0"	6'-1"	-	-	1'-9"	6'-2"	4'-8"	121±
		W=8'-4"	13'-7"	14'-7"	8'-0"	6'-1"	1'-9"	6'-2"	4'-8"			141±

Note: a_3 Bars to be Placed Approx. 2" Below Top of Inlet Cover.


W	PRE-CAST TOP SIZE	PIPE SIZE	CU. YD. CONC.
4'-4"	3'-8" 8'-4" 7 1/2"	21" & SMALLER	0.38±
5'-4"	4'-8" 6'-4" 7 1/2"	24" & 30"	0.51±
6'-4"	5'-8" 6'-4" 7 1/2"	36" & 42"	0.64±
7'-4"	6'-8" 6'-4" 7 1/2"	48" & 54"	0.77±
8'-4"	7'-8" 6'-4" 7 1/2"	60" & 66"	0.90±

GENERAL NOTES

- Concrete tops to be installed on thin mortar cushion to insure full support along brick walls. Concrete tops may be cast in place or precast. Concrete used for inlet construction shall be concrete pavement mix.
- Contractor shall have the option of constructing 8" brick masonry walls between the concrete inlet base and top on this inlet when W=6'-4" and H=7'-0" or less.
- Inlet invert shall be shaped with 8 sack sand mix concrete to create flow channels and to increase hydraulic efficiency such that the inlet will be self cleaning between all inlet and/or outlet pipes.
- The ends of all pipes installed in inlets shall be cut off flush with the inside face of the inlet wall.



BENDING DIAGRAM



CITY OF WICHITA, KANSAS
TYPE 1 CURB INLET
 INLET OPENING = 8"x6'-0"

BAUGHMAN COMPANY P.A.
 ENGINEERING, SURVEYING, & PLANNING
 316-262-7271 • 315 ELLIS • WICHITA, KANSAS 67211

PROJECT NUMBER
1488 PPS (807861)

DESIGN C.O.W. DRAWN STAFF APPROVED DATE 11/04 SCALE NONE SHEET 2 OF 4