



GENERAL NOTES

Fabric base reinforcement shall be an approved grid. Fabric base reinforcement shall be installed in accordance with manufacturer's recommendations. Crushed rock shall be uniformly graded from 1 - $\frac{1}{2}$ " maximum size to not more than 10% passing a No. 200 sieve. Rock quality shall be the same as specified for coarse aggregate for concrete mixes.

Rock base is to be compacted and smoothed with a steel faced roller prior to placement of asphalt. Tack coat will not be applied to rock base.

A tack coat of emulsified asphalt (SC-1H or CSS-1H) shall be applied to an approximate rate of 0.05 gallons per square yard between each lifts of asphaltic material.

Bituminous base and asphaltic concrete wearing surface shall be placed with a laydown machine having automatic controls for line and grade.

Construction joints in each lift shall be staggered a minimum distance of one (1) foot from joints in preceding lifts and placed so that a joint will be constructed on the centerline of the top lift.

The asphaltic concrete pavement between the combined curb and gutter shall be paid as square yards of of pavement.

STREET NAME	"WL"	"M"	"WR"	STATION	CENTER LINE	ROW DIMENSION	MEDIAN DESCRIPTION	SLOPE	ROCK THICKNESS	PAVEMENT THICKNESS	COMMENTS
46th St S	25'	10'	15'	0+50.00	32' Lt.	84'	RESERVE "B"	3.125%	5"	5"	Begin Sign
	25'	10'	15'	0+77.00	32' Lt.	84'	RESERVE "B"	3.125%	5"	5"	End Sign
	25'	0'	25'	0+80.00	32' Lt.	84'	N/A	3.125%	5"	5"	End Median
	25'	0'	25'	1+22.10	32' Lt.	84'	N/A	3.125%	5"	5"	Begin Transition
	15'	0'	15'	1+97.70	32'	64'	N/A	3.125%	5"	5"	End Transition
	15'	0'	15'	4+80.00	32'	64'	N/A	3.125%	5"	5"	Begin Return
	15'	0'	15'	5+54.00	32'	64'	N/A	3.125%	5"	5"	End Return
	15'	0'	15'	7+64.00	32'	64'	N/A	3.125%	5"	5"	Begin Return
	15'	0'	15'	8+38.00	32'	64'	N/A	3.125%	5"	5"	End Return
	15'	0'	15'	12+59.03	32'	64'	N/A	3.125%	5"	5"	Begin Return
	15'	0'	15'	13+69.03	32'	64'	N/A	3.125%	5"	5"	End Return
Flora	15'	0'	15'	0+37.00	32'	64'	N/A	3.125%	5"	5"	End Return
	15'	0'	15'	1+26.17	32'	64'	N/A	3.125%	5"	5"	Connect to
DORIS	15'	0'	15'	0+37.00	32'	64'	N/A	3.125%	5"	5"	End Return
	15'	0'	15'	1+47.00	32'	64'	N/A	3.125%	5"	5"	End of Pvmt.

