


NOTE:
Concrete Tops to be installed on thin mortar cushion to insure full support along brick walls. Concrete tops may be cast in place or precast. Concrete used for inlet construction shall be concrete pavement mix with air entrainment.



The ends of all pipes installed in inlets shall be cut off flush with the inside face of the inlet wall



SECTION B-B



SECTION A-A

STANDARD TYPE 1-A	
CURB INLET	
OPENING = 6" x 5'-0"	
JIM ARMOUR, P.E.-ACTING CITY ENGINEER	
PROJECT NUMBER	INDEX CODE
468-83644	765774
DATE	SHEET
FEB 03	10 OF 48