





WELDED STRUCTURAL STEEL GRATE
Weight 663 Lbs. Each
(3 Required)




PLAN
*Along 6:1 slope




VIEW A-A



PLAN



VIEW B-B




SECTION


RE-BAR SCHEDULE

Mark	Shape	No.	Length	Weight
A1	⌊⌋	8	7'-3"	38.74
A2	⌊⌋	2	7'-2"	9.57
A3	⌊⌋	1	16'-10"	11.24
A4	⌊⌋	1	16'-2 1/2"	10.83
A5	⌊⌋	1	15'-7"	10.41
A6	⌊⌋	1	14'-11 1/2"	9.99
A7	⌊⌋	1	14'-4"	9.57
A8	⌊⌋	1	13'-8 1/2"	9.16
A9	⌊⌋	1	13'-1"	8.74
A10	⌊⌋	1	12'-5 1/2"	8.32
A11	⌊⌋	1	11'-10"	7.90
A12	⌊⌋	1	11'-2 1/2"	7.49
A13	⌊⌋	1	10'-7"	7.07
A14	⌊⌋	1	9'-11 1/2"	6.65
A15	⌊⌋	1	9'-4"	6.23
A16	⌊⌋	1	8'-8 1/2"	5.82
A17	⌊⌋	1	8'-1"	5.40
B1	——	2	4'-10"	6.46
B2	——	2	9'-6"	12.69
B3	——	2	14'-2"	18.93
B4	——	2	15'-4"	20.49
B5	——	2	11'-6"	15.36
B6	——	2	7'-0"	9.35
B7	——	2	2'-6"	3.34
C	——	12	6'-9"	54.11
D	——	2	15'-6 1/2"	20.76
E	⌐	8	17'-3"	92.18
X	——	4	4'-0"	10.69

Total Rebars	438 Lbs.
Concrete	4.46 C.Y.
Structural Steel	1989 Lbs.

All Concrete Reinforcement to be #4 bars.





BENDING DIAGRAMS

CONCRETE HEADWALL NOTES

CONCRETE: Bevel all exposed edges with a 3/4 " triangular molding or finish with an approved edging tool. Concrete shall have a minimum 28 day compressive strength of 4,000 p.s.i. All pipes shall be flush cut prior to being cast into the headwall.

REINFORCING STEEL: All dimensions relative to reinforcing steel are to centerline of bar unless otherwise noted. All clearances shall be 2" unless otherwise noted. All reinforcing steel shall conform to A.S.T.M. designation A615 Grade 60 and shall be epoxy coated.

STRUCTURAL STEEL: All structural steel shall conform to A.S.T.M. designation A36. All structural steel shall be galvanized in accordance with A.S.T.M. designation A123.

PAYMENT: A deduction in concrete quantities has been made for the pipe opening. The "R.C. Headwall (48")" shall be paid for at the unit price per each including concrete, reinforcing steel, structural steel, galvanizing, excavation, backfilling and all other miscellaneous materials, labor, tools, equipment and incidentals necessary to complete the work. Quantities shown are for information only.

BRIAN D. BOUTWELL LICENSED 10889 PROFESSIONAL ENGINEER STATE OF KANSAS
6/23/05

No.	Revision	By	Date
	OAK CREEK - PHASE 1		

HEADWALL DETAILS (48")

JAMES L. ARMOUR, P.E.- CITY ENGINEER
CITY OF WICHITA PROJECT NO. 472-84209

Professional Engineering Consultants, P.A.
303 S. TOPEKA • WICHITA, KANSAS 67202
316-262-2691 • FAX 316-262-3003

Designed by	BDB, BLB	Job No.	35-04688-000
Drawn by	BJS	Date	October 2004

DSNR: BLB OPER: BJS SCALE: 1=2.67
Q:\2004\04688\000\04688-000-C-DITCHINLET(48) 08-23-2005 08:53:34 am