


**PARKING LOT ELECTRICAL**

SCALE 1" = 20'

FEEDER IDENT.	CONDUCTORS			GROUND SIZE PER SET	ISOLATED GROUND SIZE	CONDUIT SIZE PER SET
	SETS	QUANT. PER SET	SIZE			
1	1	4	#6 THHN	#6	1"	
2	1	5	#6 THHN	#6	1"	
3	1	6	#6 THHN	#6	1 1/4"	
4	1	2	#6 THHN	#6	1"	
5	1	2	#12 THHN	#12	3/4"	
6	1	2	#10 THHN	#10	3/4"	




Electrical Engineering and Design  
 349 S. Hydraulic  
 Wichita, Ks. 67211-1908  
 (316) 284-3061  
 FAX: (316) 284-3542

REVISED 1-14-04

03086-041

**PUBLIC PARKING LOT IMPROVEMENTS, 132 N. MOSLEY  
 ELECTRICAL SITE PLAN  
 WICHITA, KANSAS**



**Ruggles & Bohm, P.A.**  
 Engineering, Surveying, Land Planning  
 924 North Main  
 Wichita, Kansas 67203  
 www.rbkansas.com  
 (316) 284-8008  
 (316) 284-4621 fax  
 E-mail: info@rbkansas.com  
 472-85846

DESIGN	SVA	SHEET	11
DRAWN	SVA		
REVIEW		OF	11
UTILITY		DATE	July 18, 2003

DRAWING FILE: 3086E03.DWG  
 PROJECT NUMBER: [REDACTED]

**PLAN NOTES:**  
 1. REFER TO SHEET 10 FOR ALL CONTROL AND DISTRIBUTION REQUIREMENTS; REFER TO SHEET 4 FOR ALL LIGHT FIXTURES, BASE AND SPECIAL OUTLET "A" REQUIREMENTS.  
 2. ALL CONDUCTORS TO BE CLEARLY AND PERMANENTLY MARKED AT ALL ENDS AND JUNCTION POINTS WITH PANEL DESIGNATION AND CIRCUIT NUMBER.

18-13-05-10

S.V.A. DWG NAME: 3086E03.DWG DATE: 07/17/03 TIME: 08:24