



- Mortar used in plug construction shall be in accordance with standard specifications.
- All brick used in stack construction shall meet Grade ASTM C32 for MM and MS.
- Pipe plugs shall be *Subsidiary* to the project.

