



1. Outfall pipe needs to be min. of 15" RCP
2. Direct tapping is not recommended. (of storm sewer)
3. Is this a privately maintained system?
4. Any conflict w/ existing SS?

GRADING & UTILITY PLAN
SCALE 1/2" = 10'

EXHIBIT "C" TO ADDENDUM #3
5/16/91

SECTION INTO STORAGE
3/8" = 1'-0"

LAWRENCE E. WELLS
A R C H I T E C T
254 LAURA, SUITE 205
WICHITA, KANSAS 67211

DATE: 5-22-91
DRAWN: [Signature]
CHECKED: [Signature]
REVISED: 5-25-91

GRADING & UTILITY PLAN
DETAILS

AN ADDITION TO
THE INDEPENDENT SCHOOL
WICHITA - KANSAS

PLAN NO. C-824 PROJECT 1482

SHEET 2 OF