

1. Thermal Products, Inc. . Vacation of Utility Easement.  
No water lines in vacated 36th St. No water problem.
2. Magnolia Addition. Final plat. Area now served,  
no water problem.
3. Southglen Addition. Preliminary Plat. Existing main in  
47th Street to be tapped and interior mains extended  
as necessary to serve all lots. No water problems.
4. Pinewood Mobile Home Park Addition. Existing 16" main  
in Hydraulic to be tapped and interior mains to be extended  
as necessary to serve all lots. No water problem.
5. Fruitvale Park 2nd Addition. Final plat. Existing 12" main  
in Anna. No water problem.
6. The Park 2nd Addition. Preliminary Plat. Existing 8" main  
in Yellowstone. Main to be extended in Yellowstone Court.  
No water problem. Item B.
7. Countryside Pentecostal Holiness Church Addition. Final Plat.  
Nearest City Water at 119th St. W. & 21st N. approx.  
1 mile of 12" main would need to be extended. Suggest  
possibly holding a water petition for 8" sizing crossing  
their property to be used when development allows extension.  
No water problem. Item A.
8. Woodcrest Addition. Preliminary Plat. Existing 16" main in  
15th St. to be tapped and extended in Gatewood as an 8" main.  
No water problem. Item B.
9. Tallgrass Two Additions. Preliminary Plat. Item B, mains to  
be extended. Suggest extension of 24" main in 21st going E. from  
Webb to allow secondary feed to area. Existing 24" main in  
Webb to be tapped for interior mains.

10. Willowbend Fourth Addition. Preliminary Plat. Existing 20" main in Rock Road to be tapped. No water problem. Item B. Suggest that main crossing Rock Rd. be installed ahead of paving to avoid boring & casing.
11. Gatewood Addition. Final plat. Item B, mains to be extended. No water problem.
12. Killarney First Addition. Preliminary Plat. Existing mains in Rock Rd, 30th St., and 32nd St. Based on the proposed buildings and possible fire hydrant requirements, an 8" main has been proposed to run along the west side of the plot for building service and fire protection.
13. Cottonwood Grove Second Addition. Final Plat. Existing 12" main in 44th St. S. to be tapped for interior mains running along reserves. Services shall be set in conjunction with water main project. Item D. Verify which old water projects need to be abandoned.
14. Aaron G. Fair. Dedicate street R/W. Existing main along west side of Leonine. No water problem.
15. Chester Robinson. Dedicate additional utility easement. No city water mains in area. No water problem.