

## Sub-Division 4-25-85

- 1 Access Control Lot 1 Block B, Airport Industrial Addition.  
No Problem
- 2 Vacation of Platted Setback Lot 1 Block B, Mona Key  
Mollock Addition. No Problem
- 3 St. Francis Regional Med. Center Access Control Vacation.  
No problem
- 4 Red Oaks Homes Utility Esm't vacation. No problem
- 5 Golden Hills Addition. Item B. Existing 16" AC Main in  
Central. Interior mains to be petitioned. Also  
discuss possibility of a supply line being run in  
119th St. going north from Central to North line  
of the Addition. An argument was made by D. Linn  
about the supply line in Woodbridge which could be  
used to support the extension of such a supply line.
- 6 Midtown Third Addn. Access to water main in the  
vacated area of Water street to be maintained.
- 7 Phillippi Addition. Item A, No water available
- 8 Schimming Addition. 6" Water Line on W. side of  
Yale. No problem
- 9 Sherwood Acres Mobile Home Park. Item C. 12" Water  
Main to be extended as necessary across frontage  
on 47th St., 8" to be extended N. along interior  
St. to and including Cut-de-Sac.
- 10 Sanctuary Addition. Item B, No water available, No Problems.
- 11 S. Voge End Addition. Item F. End of existing 8" Water main  
located 60' N and 8' W of NE Property Corner  
of 11th St. N. & Smith. End of existing 6" main  
located 243' U.W. PL of Anna 8' SNPL 12th.  
Either main could be extended if R/W exists on 12th.  
May be extended by petition or Private Contract. To

- 12 C.C.R. Addition. Item C. End of existing 12" Main at N line of Security Storage Properties. 12" to be extended N along Rich Road to N. line of CCR Addition.
- 13 Scholfield - Hatched Addition. Water as shown. No Problem.
- 14 Carpenters 201 Addn. Item C. 8" Water to be extended from Seneca to West line of Lot 1 (E Line of Mortinson).
- 15 First Presb. Church. No problem
- 16 Amortibank. No problem
- 17 Voelker No Problem
- 18 No Problem

Note: Items 15-18 No problem unless prior esmt.

19 No Problem