

Water

Pre-Sub June 20, 1985

1. Karl Solomon. Vacation of utility easement. No water lines in easement. No problem.
2. Broadway Christian Church. Alley vacation. No water lines in alley. No problem.
3. John M. Vest. Utility easement vacation. No water lines in easement. No water problems.
4. Golden Hills Addition. Item B. Water to be extended from existing 16" main in Central. Suggest supply line in 119+L to be run to allow for system reinforcement.
5. East Hampton Addition. Item B. Water to be extended from existing 24" main in Woodlawn. Proposed layout is satisfactory if main is extended across lot 42 Block 2.
6. Windemere Addition. Item B. Water mains to be extended from Oxford.
7. Dietz Addition. Existing water mains in Seneca and 32nd St. No water problems.
8. Dellrose Church of Christ Addition. Item A is in error. Existing 12" Watermain in Greenwich Road. Existing 8" Water main in Osie. Both may and should be extended into the Addition. Application for water outside city and Restrictive Covenant required.
9. Bader 3rd Addition. Item A. Water to be extended from 8" 2nd St.
10. Kuehn Addition. Item D. Existing water main in 55+L St. So. ends at Mosley from the West. Existing water in Hydraulic ends approx 250' S of Campus. Interest expressed by several land owners as to the possibilities of extending water main.

11, 12 Virginia Reynolds. No water problems.