

THE CITY OF WICHITA

OFFICE OF DEPARTMENT OF ENGINEERING DATE April 30, 1981

TO Jack Galbraith, Chief Planner

FROM Chris Breitenstein, Drainage & Flood Control Engineer

SUBJECT Subdivision Agenda - April 30
Approval of Plans OR
Approval Subject to Various
Stipulations

Cedar Lakes Plaza 2nd Addition--Site Grading Plan - Entire lot
should be graded to above 171.6, such that it will drain
when Harry Street is improved to arterial standards;
otherwise there needs to be a private storm water sewer.


Willo-Esque 5th Addition

Northwest Village 3rd Addition

Twin Oaks Addition - Site Grading Plan should be submitted to
Engineering before obtaining building permit.

Green Addition

Caliendo 7th Addition


Chris Breitenstein
Drainage & Flood Control
Engineer

CJB:md

cc: Louise Olivarez
Mike Lindebak

PLAT NAME NORTHWEST VILLAGE 3RD ADDITION

GENERAL DESCRIPTION South of 17th Street on the east side of Tyler Road

LOCATION: Section _____ Township _____ Range _____ Verified by: _____

BENCH MARK or ELEVATION DATUM _____ Verified by: _____

OWNER Wesley Medical Endowment Foundation

ENGINEERS Professional Engineering Consultants, 355 Ellis, 263-1107

ARCHITECTS _____

SKETCH PLAT SUBMITTED _____

PRELIMINARY PLAT SUBMITTED _____

FLOOD CONTROL RECOMMENDATIONS _____

SUBDIVISION COMMITTEE ACTION _____

FINAL PLAT SUBMITTED Permission to draw onto private prop. Drainage letter Reg'd

FLOOD CONTROL RECOMMENDATIONS No Comment

SUBDIVISION COMMITTEE ACTION Approved 4-30-87

MAPC ACTION _____

BOARD OF CITY COMMISSIONERS ACTION _____

BOARD OF COUNTY COMMISSIONERS ACTION _____

RECORDED _____

REMARKS _____