



MEMO

TO: City of Wichita PROJECT NO. 32-80305-042
Engineering Department PROJECT: Northwest Village
City Hall-7th Floor Streets and Storm Drains
ATTN: Mr. Steve Lackey, P. E. DATE: October 24, 1980

COPIES TO: _____
Project File _____ FROM: Charles S. Brown, P. E.
_____ REFERENCE: Predesign Mtg.

PLEASE ADVISE IMMEDIATELY OF ANY MISCONCEPTIONS OR OMISSIONS YOU BELIEVE TO BE CONTAINED HEREIN.

As per our meeting this date at City Hall, the following items were discussed:

1. Radii at the intersections of Thurman and Robin Road and at the intersection of Thurman and Tyler Road are to be 30' (face curb).
2. Petitions have been approved by City Commission. Project numbers will be available next week after commission approval.
3. The temporary cul-de-sacs shall be constructed with full depth asphalt at the normal street width, roll-back curb and gutter, and 5" asphalt behind curb to the 35' radius limit.

