

1. Tallgrass Commercial Third. Existing 8" main and fire hydrant in area to be vacated. If main to be removed, developer should be charged all costs. Current Benefit District special assessments shall remain against property.
2. Briarwood Estates 5th. Item C. Existing 8" main in Penderosa joins E. from Alderny. Existing 12" in 13th. Existing 12" in 119th stops N. of Alderny, coming from 13th. If possible, 12" to be extended along 119th S. to South line of Alderny or to S. line of project. If 119th 12" not possible, existing water will serve the project.
3. Davidson and Frey Addition. ~~See~~ Water main available.
4. Maize Avenue Addition. Existing water (16" in Maize, 12" in Carr) to area. No water problems.
5. Hadijski Addition. Existing 8" water in water easement along E. side of Reserve B. Depending on use of Reserve B, additional easement to serve the property may be necessary to cross Reserve B.
6. Air Park Northeast. Existing rural water district line is in 37th and goes N. & S. in Greenwich. The nearest City of Wichita water line is in Webb Rd. at 39th, or in Webb Rd. at 37th. Either main could be extended to Greenwich. 20" Supply line required. Item C.
7. Jeff Bruce Addition. Existing 6" water in Cleveland. No water problems.
8. First Dixon Addition. Existing 2" water main in New York. No water problems.
9. West Meadows Addition. Nearest water at 13th and Cedar Park (W. of 119th).

10. Maria Addition. Item B. Existing 6" Main in Lewis. Item C, additional water easement will be necessary in order to move water main out from under proposed pavement.
11. de Paul Addition. Existing water in Central, Kessler, and along the West side of the plat north of the existing hydrant. No water main in Newell.
12. Maxwell Third Addition. Item L. Existing water main shall be abandoned, any cost charged to developer.
13. Pine Bay Estates. Existing 16" main in Hydraulic ends at approximately 200' N. of 55th St. Much interest has been expressed in running city water to the area. If possible would suggest a supply line benefit district be tried. Ground Water is of poor quality, and once wells are allowed, extension of city water becomes more difficult.
14. A.T. & SF RR Street R/W Dedication. No water problems.
15. A.T. & SF RR Street Dedication along Santa Fe. No water problems. Existing 8" along existing R/W on E side 8' W of E.R. Need to verify no prior water easement along R/W.
16. A.T. & SF Street Dedication along Santa Fe, S of 34th. No water problem.
17. Hamel & Rew Land Company. Utility Esmt. No water problem.
18. Woodlawn Development Co. Utility Esmt. No water problem.
19. Other Matters.