

Drc-Sub Aug. 1, 85
①

1. Builders Inc. Vacation of Alley. No water problems.
2. Robert L. Moore. Vacation of Fire Lane. No water problems.
3. Everett Long. Vacation of Drainage R/W. No water problem.
4. Richard A. Hiebsch. Vacation of Utility Esm't. No water problem.
5. West Meadows Addition. Existing 16" AC in 135th St. West, going south from Rolling Hills, existing 12" A.C. in 13th St. N. going E. from Cedar Park. To extend water would be possible with a "supply line" benefit district, 12" to be extended in 13th. Item A. No water available.
6. E. A. Niss Addition. Item A. Nearest water at Keywest and Meridian. No water available.
7. Central-Maize Second Addition. Existing 16" AC Water mains in Central and Maize. No water lines shown on preliminary plat. No water problems.
8. Midtown Third Addition. Existing water main in 60' Utility Esm't. No water problem.
9. Leonard A. Garnett Addition. Existing 12" Water main in 31st St. S. 6" or 8" to be extended north from 31st to serve Lot 2. Sizing depends on fire hydrant requirements.
10. A. J. Sorries 9th Addition. Existing 8" water in Woodrow Ct. No water problem.
11. Hybridtech Wheat Addition. Nearest water at Keywest and Meridian. Item A.
12. Home State Bank Addition. Item A. No water available.
13. C.C.R. Addition. Item C. 12" Main to be extended along Rock Rd. from Security Storage Properties to N. line of C.C.R. Addition.

Pre-Sub Aug. 1, 1983

②

14. Kuhn Addition. Item D. Wells to be allowed. Existing water going West from Masley in 55th.
15. Ford M. Duke. Street Dedication. Existing water line now in Curtis St. going N. from Robinson. Existing water easement along a portion lots 18 and 19, not being utilized.
16. Tallgrass Company. Granting Utility Easement. No water problem.
17. Other Matters.