

Pre-Sub 3-13-86

1. Bent Tru Co. Vacation of utility esmt, fire lane, drainage, etc.
No water problem.
2. Woodspring Third Addition. Preliminary Plat. Item B, mains to be extended. No water problem. Existing main in Woodspring.
3. Mulberry East Third. Final plat. Mains to be extended from 37th St. No. and tied into Rock Road. No water problem.
4. Woodbridge 3rd Addition. Final Plat. Item B, mains to be extended. From Parkridge, No water problem, Existing 12" in 119th St.
5. Cannon Ball Addition. Final Plat. Existing main in Maple, no water problem.
6. Goebel Bros. 2nd Addition. Preliminary Plat. X'sty 12" in Anna, X'sty 24" on N. side Douglas, X'sty 8" on S. side Douglas. Need to determine cost of tapping 24" for service as opposed to tapping 8" on S. side. Would prefer tapping 8" if at all possible.
7. Other matters.