

Queen City

Hydraulic & Wassall 10-67, SWS #48

Area = .4 AC

Drain to Wassall then west to
Hydraulic. Inlets at Wassall &
Hydraulic connect to 30" SWS under
Hydraulic and flow south.

Drainage concept is O.K.