

1. Industrial Park Development Company. Street R/W Vacation. Existing U.L. on N side of 37th. No water problem.

2. Robert Cox. Utility Easement Vacation. No water problem.

3. Westway Addition. Final Plat. Existing main in Seneca and Pawnee. Existing structure now served. PROBLEMS! 8" line shown is probably correct, however not all water lines are shown. Request 20' Utility esmt. for 8" main going west x SW from northerly end of 8" main shown. See notes on sketch plat. Consultant to determine location of 8" mains from Water Dept.

City. 4. Simon Industrial Park Addition. Preliminary Plat. Park City. No city water available. No water problem.

5. Huntington Place Addition. Final Plat. Item D, water to be extended. No water problems.

6. Vanderhoff Gardens Second Addition. Item B, water to be extended, no water problem. How will lot 3 be served by water?

City. 7. Gray's First Addition. Final Plat. Item B, main to be extended.

8. Burlington Northern Industrial Center Second Addition. Existing main in Ohio, no water problem.

City. 9. Wolke Addition. Preliminary plat. Item C, no city water available. No water problem.

10. The Dugan Centre. Final plat. Item B, mains to be extended. No water problem.

11. C. Wayne Kerr. Utility Esmt. Granting. No water problem.

Pre-Sub
5-22-86

12. The Board of Park Commissioners. St. R/W Dedication
No water problem.
13. Ted & Ken Prichard. Grant Utility Esmt. Probably
no problem.
14. Ted & Ken Prichard. St. R/W Dedication. No water problem.
15. Other Matters.