

SUBDIVISION COMMITTEE
METROPOLITAN AREA PLANNING COMMISSION

AGENDA ITEM NO. 7
October 8, 1998

STAFF REPORT
(One-Step Final Plat)

CASE NUMBER: S/D-9893 -- NORTHEAST MAINTENANCE SUBSTATION
ADDITION

OWNER/APPLICANT: City of Wichita, Attn: Dan Grohn, 455 N. Main, 8th Floor,
Wichita, KS 67202

SURVEYOR/ENGINEER: Professional Engineering Consultants, 303 S. Topeka, Wichita, KS
67202

LOCATION: Southwest corner of 33rd St. North and Hillside

SITE SIZE: 8.35 acres

NUMBER OF LOTS

Residential:
Office:
Commercial:
Industrial: 2
Total: 2


35 # 23

MINIMUM LOT AREA: 1.89 acres

CURRENT ZONING: LI, Limited Industrial

PROPOSED ZONING: Same

VICINITY MAP



Note: This is a replat of the Northeast Substation Addition in addition to unplatted land to the west.

STAFF COMMENTS:

- A. Existing municipal services appear to be available to serve this site. City Engineering needs to verify if any other additional guarantees are required.
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. City Engineering needs to comment on the status of the applicant's drainage plan.
- D. Traffic Engineering needs to comment on the platted access controls. The plat denotes one access opening along Hillside. Access controls dedicated along K-96 need to be referenced on the final tracing.
- E. If any drainage occurs onto K-96, a letter shall be provided from KDOT indicating their agreement to accept such drainage.
- F. The dedication of right-of-way for 33rd St. North needs to be referenced in the plat's text.
- G. This property is within a zone identified by the City Engineers' office as likely to have groundwater at some or all times within 10 feet of the ground surface elevation. Building with specially engineered foundations or with the lowest floor opening above groundwater is recommended, and owners seeking building permits on this property will be similarly advised. More detailed information on recorded groundwater elevations in the vicinity of this property is available in the City Engineers' office.
- H. Traffic Engineering needs to comment on the need for improvements to Hillside.
- I. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)

S/D 98-93 -- One-Step Final Plat of NORTHEAST MAINTENANCE SUBSTATION
ADDITION

October 8, 1998 - Page 3

- J. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- K. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- L. The applicant is advised that various State and Federal requirements [specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147] for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- M. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- N. Perimeter closure computations shall be submitted with the final plat tracing.
- O. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- P. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- Q. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat. This will be used by the City and County GIS Department.