

Note: This site is located in the County within three miles of the Wichita City limits. It is in an area designated as "agricultural" by the Wichita-Sedgwick County Comprehensive Plan. Lot developments of this type are contrary to the intent of the Comprehensive Plan; however, the MAPC and County Commission have chosen not to create an Agricultural Zoning District to protect against this type of development.

After dedication of right-of-way for adjoining streets, seven of the eight lots will consist of less than 4.5 acres, in violation of the Subdivision regulations for lots serviced by sewage lagoons. Due to insufficient lot size, MAPD Staff recommends the Subdivision Committee deny approval of this plat. Should denial occur, the applicant must first formally request the Subdivision Committee decision be appealed to the Planning Commission prior to any action being taken by the governing bodies. Should the Subdivision Committee approve this plat, the following conditions shall apply.

STAFF COMMENTS:

- A. Since neither municipal water nor sanitary sewer is available to serve this property, the applicant shall contact the Environmental Health Division of the Health Department to find out what tests may be necessary and what standards are to be met for approval of on-site sewerage facilities and water wells. A memorandum shall be obtained specifying approval. The lots will consist of less than 4.5 acres, in violation of the Subdivision regulations after dedication of right-of-way for adjoining streets.
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. County Engineering needs to comment on the status of the applicant's drainage plan.
- D. County Engineering needs to comment on the access controls. The plat denotes one access opening along 85th St. North for the lot adjoining Oliver, and one access opening per lot along Oliver.
- E. The Subdivision regulation require a 50-ft half street right-of-way for section line roads. The plat denotes a contingent right-of-way dedication for Oliver (currently 30-ft half-street right-of-way) and 85th St. North (currently 40-ft half street right-of-way). County Engineering needs to comment on the need for an outright dedication.

- F. Based upon the platting binder, the site is in the ownership of another party which must be made a signatory to the plat or a document provided that such interest is no longer involved in this site.
- G. The City Council signature block needs to be added as this plat is located within three miles of the City.
- G. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- H. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- I. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- J. The applicant is advised that various State and Federal requirements [specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147] for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- K. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- L. Perimeter closure computations shall be submitted with the final plat tracing.
- M. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.

- N. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.

- O. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in Release 13 version of Autocad. This will be used by the City and County GIS Department.